

# Battery/Peripherals Enclosure

## Product Installation Document

PN 50295:B 07/24/2001 ECN 01-250

This cabinet consists of a backbox with an integral, lockable door that is hinged on the bottom to swing down for access.

It is designed to be mounted a minimum of 6 inches (15.24 cm) below the fire alarm control panel (FACP). When both cabinets are surface mounted, the knockout in the bottom-right corner of the FACP will line up directly above the knockout in the top-right corner of this enclosure.

This enclosure should be mounted in a clean, dry, vibration-free area, using the six holes provided.

Note: The enclosure has 0.875 in. (2.2225 cm) knockouts which accept standard 0.75 in. (1.905 cm) conduit.

