



# ADT

## SUPPLEMENT FOR ADT-TCM-4

(For MANUAL #A15924 Rev. B)

Document 50333 Rev A 6/27/95 ECN 95-305


*Add the following note to the illustration of the CRE-4 on page 9:*

If using a mix of power-limited and nonpower-limited circuits, maintain 0.25" spacing between power-limited and nonpower-limited wires and enter/exit enclosure through different knockouts.

*Replace the paragraph titled **Timers Coders** on page 13 with the following:*

**Code Options**

March Time must be selected in **Code Options**.



When the **EXTENDED PROG**

LED is on, set the yellow LED on Notification Circuit 1 to select March Time Code.

*Replace the paragraph titled **Timers Coders** on page 18 with the following:*

**Code Options**

Temporal Code must be selected in **Code Options**.

When the **EXTENDED PROG**

LED is on, set the yellow LED on Notification Circuit 1 to select Temporal Code.

