

Supplement For LCD-40 Manual (Doc.#50327 Rev. A)

Document 50396 Rev A 12/18/95 ECN 95-530

Pages 11 and 12 - It is stated that the LCD-40 can be surface or semi-flush mounted **ONLY** in a three-gang electrical box. A three-gang electrical box can be ordered from Fire•Lite, Part Number 10103. You may use the Fire•Lite box or an equivalent three-gang electrical box with a minimum depth of 2.5".

CAUTION! The LCD-40 can **ONLY** be mounted in a three-gang electrical box, Fire•Lite P/N 10103 or equivalent, with a minimum depth of 2.5". The LCD-40 **cannot** be mounted in three gangable electrical switch boxes connected together.

