

## AC Loss Reporting Delay Supplement

Document 52452 Rev A 11/10/04 ECN 04-639

*Refer to **AC Loss Reporting Delay (Programming Address 64)** in the Programming Options section of the manual.*

Replace the AC Loss Reporting Delay Time settings in the manual with the following information.

Enter a digit of *1 - F*, corresponding to the number of hours to be delayed in reporting loss of AC power. The factory default setting is *2* for a 2 hour time delay. A *0* entry causes immediate reporting of AC loss. If 24 hour battery backup is being employed, select from choices *0* through *8*. If 60 hour backup is used, select from choices *9* through *F*.

Valid entries are *0* to *9* and *A* to *F*, corresponding to the following reporting delay times:

0 = no delay	8 = 11 hours
1 = 1 hour	9 = 15 hours
2 = 2 hours	A = 16 hours
3 = 6 hours	B = 17 hours
4 = 7 hours	C = 20 hours
5 = 8 hours	D = 21 hours
6 = 9 hours	E = 22 hours
7 = 10 hours	F = 23 hours