
# Linear RA-2400

# REMOTE ACCESS SOFTWARE



# Reference Manual for Programming the PERS-3600 Personal Emergency Reporting System

WRITER'S NOTE: This publication could contain technical inaccuracies or typographical errors. Changes are periodically made to the information herein; these changes will be incorporated in new editions of the publication. Linear may make improvements and/or changes in the product(s) and/or software described in this publication at any time.

MS-DOS®, Windows™, WindowsNT™, Windows95™, Windows98™, WindowsME™, WindowsXP™ and Windows2000™, are registered trademarks of Microsoft Corporation.

Pentium® is a registered trademark of Intel Corporation.

IBM® is a registered trademark of International Business Machines Corporation.

# FOR TECHNICAL ASSISTANCE CALL: Linear Technical Services: 1-800-421-1587

# TABLE OF CONTENTS

1.	INTRODUC	TION	. 1
	1.1	SOFTWARE DESCRIPTION	. 1
	1.2	SYSTEM REQUIREMENTS	. 2
	1.3	PROGRAMMING OUTLINE	. 3
	1.4	PROGRAM INSTALLATION	
	1.5	TESTING THE MODEM	. 5
2.	OVERVIEW	1	. 6
	2.1	STARTING THE PROGRAM	. 7
	2.2	NEW WINDOW	. 7
	2.3	MENU BAR.	. 8
	2.4	ACCOUNT PROFILE WINDOW OVERVIEW	
3.	COMMUNIC	CATIONS SETUP	11
	3.1	COM PORT	
	3.2	SPEAKER	12
	3.3	CONNECTION OPTIONS	13
	3.4	MODEM INITIALIZATION STRING	14
4.	CREATING	A CUSTOM ACCOUNT PROFILE	15
	4.1	NEW WINDOW	
	4.2	CUSTOMER INFORMATION	17
	4.3	CONSOLE REMOTE AUDIO PASSWORD	18
	4.4	CONSOLE ALARMS	19
	4.5	CONSOLE AUDIO	20
	4.6	SENSORS	21
	4.7	COMMUNICATOR MAIN	23
	4.8	COMMUNICATOR ROUTING AND NUMBERS	24
	4.9	COMMUNICATOR ENABLED REPORTS	25
	4.10	COMMUNICATOR 4 BY 2 FORMAT	26
	4.10.1	4 BY 2 POINT-TO-POINT ALARM CODES	27
	4.10.2	4 BY 2 POINT-TO-POINT TROUBLE CODES	28
	4.10.3	CONSOLE REPORT CODES	29
	4.10.4	4 BY 2 GENERAL ALARM CODES	
	4.11	ADEMCO CONTACT-ID REPORT CODES	
5.	REMINDER	MESSAGES	32
	5.1	REMINDER SCHEDULE SETUP	33
	5.2	1-DAY REMINDER SCHEDULE	34
	5.3	2-DAY REMINDER SCHEDULE	
	5.4	7-DAY REMINDER SCHEDULE	
	5.5	30-DAY REMINDER SCHEDULE	37
6.	SENDING A	AND RECEIVING CONSOLE DATA	
	6.1	ACCESSING THE SEND/RECEIVE WINDOW	
	6.2	CHOOSING AN ACCOUNT PROFILE	
	6.3	CONNECTING TO A CONSOLE	
	6.4	TURNING THE ACTIVITY TIMER ON & OFF	
	6.5	SETTING THE CONSOLE'S CLOCK	44
	6.6	SENDING DATA	45
	6.7	RECEIVING DATA	
	6.8	DISCONECTING FROM THE CONSOLE	
	6.9	CLOSING RA-2400	

# 1. INTRODUCTION

1.1	SOFTWARE DESCRIPTION
1.2	SYSTEM REQUIREMENTS
1.3	<b>PROGRAMMING OUTLINE</b>
1.4	PROGRAM INSTALLATION
1.5	<b>TESTING THE MODEM</b>

# 1.1 SOFTWARE DESCRIPTION

The software described in this manual supports the programming of a variety of Linear products. These instructions are focused on the Model PERS-3600 Personal Emergency Reporting System. The screen snapshots in this manual were made with the software running on the Windows XP<sup>™</sup> operating system.

Refer to the RA-2400/PERS-2400A Programming Reference Guide P/N: 217163 for details on programming the PERS-2400A Personal Emergency Reporting System.

Refer to the RA-2400/DVS-1200, DVS-2400, DUAL-824 & DVS-2408 Supervised Wireless Security Systems Programming Reference Guide P/N: 217473 for details on programming these other models.

#### What is the RA-2400 Remote Access Software?

The RA-2400 Remote Access software is a communications program designed to work with Linear's PERS-3600 Personal Emergency Reporting System. The software runs on an IBM PC or compatible computer and connects to the console through the standard telephone network, or to the Console directly, with the computer's modem. This 32-bit software runs under all versions of the Windows<sup>™</sup> operating system.

RA-2400 software programs all features of Linear PERS Consoles (excluding learning transmitters into the Console). RA-2400 sets the options for: Console alarm, audio, and sensors; communicator telephone numbers, call routing, formats, reporting codes, account numbers, and reminder message times.

The RA-2400 software has a large help file that can be accessed at any time by selecting "Contents" from the "Help" menu or by pressing the F1 key.

#### How does RA-2400 connect to a Console?

Remote Access communicates with the Console over the same telephone line the Console uses to send communicator reports. Remote Access can also connect to the Console without a telephone line by directly connecting the Computer modem's LINE jack to the Console's LINE jack using a standard modular telephone cable.

With a telephone line connection (*remote dialing*), a special dialing procedure is used. First, Remote Access dials the phone number specified for the Console. Remote Access waits long enough for the phone to ring two or three times, then hangs up. Next, Remote Access waits, then dials again. This second call is answered on the first ring by the Console.

With a direct connection (*local cable connection*), Remote Access prompts the user to place the Console in Test Mode and press the Console's HELP button to establish the connection.

Once the connection is made, the Console will check if its remote access password matches the calling software's password. If the passwords match, access is granted.

#### Do I have to be connected to a Console to make programming changes?

Since Remote Access knows the Console's programming structure, you can modify an Account Profile without being connected to a Console. This means you can set all of the values for a specific Console configuration and then connect to a unit and send all of the values that you have set. This is referred to as off-line Console configuration.

#### How do I change Console settings while on-line?

While on-line with the Console, make any changes to the Account Profile then send the data to change the Console.

#### Can I make a template with the typical settings for all of my accounts?

Programming "templates" can be created to speed up programming multiple Consoles. Common settings, such as the Central Station telephone number, communicator format, Console and communicator configurations which are shared by all of your accounts can be stored in an Account Profile and used as a template. That template file can be used as a basis for creating each customer Account Profile file. See "Using Profile Copies" in the Help contents for more information on creating a template.

#### How do I add and remove the program's password?

A password can be set to restrict the RA-2400 to authorized users only. To add a password, select "Change Password..." from the "Options" menu. Enter the password in the "New Password" field. Verify it by entering the password again in "Retype New Password" and click OK. To remove the password, enter your password in "Old Password", don't enter anything in both the "New Password" and "Re-type New Password" fields and press OK.

# 1.2 SYSTEM REQUIREMENTS

# Minimum System Requirements:

IBM compatible 486 personal computer with 8 MB RAM

Windows 95/98/NT/ME/XP/2000 operating systems

VGA monitor

Name brand modem that is capable of 300 baud (BELL 103 compatible)

Hard disk drive with 10 MB available space for the software plus 18KB available space for each Account Profile file.

CD-ROM drive

## **Recommended System:**

Pentium or better based personal computer with 16 MB RAM or more

Windows 95/98/NT/ME/XP/2000 operating systems

SVGA or better video card

Microsoft compatible mouse

Name brand modem that is capable of 300 baud (BELL 103 compatible)

Large hard disk drive (1000 Account Profiles use about 20 MB)

CD-ROM drive

# 1.3 PROGRAMMING OUTLINE

Use the following programming outline to guide you through the steps required to set up the RA-2400 software and program a PERS Console. Many of the programming options available in the RA-2400 program can be left in their default settings, and do not need to be changed for most installations.

# 1. SETUP RA-2400 SOFTWARE

- Install the software on your computer (Section 1.4).
- ✦ Test your computer's modem (Section 1.5).
- ◆ Start the RA-2400 program (Section 2.1).
- Set the Communications Setup options (Section 3).

# 2. CUSTOMIZE AN ACCOUNT PROFILE

- ♦ Open a new Account Profile (Section 4.1).
- Enter customer information (Section 4.2).
- ♦ Set the Console's access code (Section 4.3).
- ◆ Set the Console's alarm options (Section 4.4).
- ◆ Set the Console's audio options (Section 4.5).
- Enable the Console's communicator and choose a communicator format (Section 4.7).
- Choose the communicator's account number, telephone numbers, and trouble report routing (Section 4.8).
- ◆ Set the communicator status reporting options (Section 4.9).
- ◆ Set the Reminder Message schedules (Section 5).

# 3. PROGRAM THE CONSOLE WITH THE ACCOUNT PROFILE

- Choose an Account Profile (Section 6.2).
- ✦ Connect to the Console (Section 6.3).
- ✦ Turn the Console's Activity Timer on or off (Section 6.4).
- ✦ Set the Console's clock (Section 6.5).
- ✦ Send the data to the Console (Section 6.6).

## **IMPORTANT:**

# AFTER ANY PROGRAMMING CHANGES ARE MADE TO A CONSOLE, PERFORM THOROUGH TESTING TO VERIFY THAT THE CONSOLE OPERATES AS INTENDED.

# 1.4 PROGRAM INSTALLATION

The RA-2400 Remote Access Program software is supplied on a CD-ROM. The latest version of the software is also available on Linear's web site at: www.linearcorp.com. The installation program will create a directory on your hard disk drive. Be sure that you have at least 10 megabytes free on the hard disk for the program and any Account Profile files that you create.

# To Install the Remote Access Program:

- The first step is to close all other running programs.
- ◆ Place the Remote Access CD into your computer CD-ROM drive.
- The installation process should start automatically. If the CD does not auto run, click START, then RUN... and browse to find RASETUP.EXE on the CD. Double-click on RASETUP.EXE and the install program will start.
- Click the Next button to install the Remote Access software.
   Follow the on-screen instructions as the setup program creates the directory and copies the program files onto your hard disk.
   A Remote Access icon will be created on your desktop.
- If you are performing a reinstallation, or an update, you will be prompted to uninstall RA-2400 first. After the uninstall is completed, browse to the appropriate drive letter for your CD drive and double-click on RASETUP.EXE. Then follow the on-screen steps to install the Remote Access software.
- NOTE: If Windows asks whether to replace existing .DLL files, first answer NO. If RA-2400 fails to run, re-install RA-2400 and answer YES to replace existing .DLL files.
- Remove the CD and store it in a safe place.

#### To Remove the Remote Access Program:

- Press START, SETTINGS, CONTROL PANEL. Double-click on ADD/REMOVE PROGRAMS.
- Select Linear RA-2400 and click ADD/REMOVE or CHANGE/ REMOVE button depending on your Windows Operating system.

1 Prone and Modem Options		
Phone and Modem Options	Standard 2400 bps Modem Properties	×
Dialing Rules Modems Advanced	General Modem Diagnostics Advanced Driver	
The following <u>m</u> odems are installed: Modem Altached To Standard 2400 bps Modem CDM1	Modem Information     Field Value     Hardware ID mdmgen24	
	Command         Response           AT00V1E0         Success           AT+GMM         COMMAND NOT SUPPORTED           AT+FCLASS=7         0.1.2           AT+GLS=2         COMMAND NOT SUPPORTED           AT+GCI?         COMMAND NOT SUPPORTED	
Add Bernove Properties	Clogging Append to Log	
OK Cancel Apply	OK Cancel	

Before you run the Remote Access Program, be sure that the computer is running correctly and that the modem is installed and working properly.

## To Test the Modem:


Windows Control Panel can be used to test the modem and determine what COM port it is connected to.

- ✦ Press START, SETTINGS, CONTROL PANEL.
- Double-click on PHONE AND MODEM OPTIONS.
- Click on the MODEMS tab. The modem and the COM port used should be shown.
- Note the COM port number. It's used when setting COM port in the RA-2400 Communications Setup window (see Section 3.1).
- Click the PROPERTIES button and select the DIAGNOSTICS tab.
- Click the QUERY MODEM button. If the modem is connected and working properly, the Modem Information window will display detailed Command and Response modem information. If the modem is not working properly, Windows will notify you.

# 2. OVERVIEW

2.1	STARTING THE PROGRAM	7
2.2	NEW WINDOW	7
2.3	MENU BAR	8
2.4	ACCOUNT PROFILE WINDOW OVERVIEW	0

NOTE: Experienced computer or PC users should find that entering data and navigating around the RA-2400 program dialog boxes is similar to most other Windows programs. New users, or users unfamiliar with running Windows applications, should refer to the Windows help file for details on using Windows.



# To Run the Program:

 Double-click on the RA-2400 desktop icon or press START, point to ALL PROGRAMS, RA2400 and click on RA2400.

# 2.2 NEW WINDOW

New	×
New PERS-3600 V1.0 PERS-2400A V2.0 PERS-2400 V1.0 to V1.7 DUAL-824 V2.1 to V2.4	OK Cancel <u>H</u> elp

## **PURPOSE:**

To select an Account Profile template for the type of unit being programmed.

# **USER RESPONSE:**

- Select PERS-3600 V1.0
- Press OK.

The RA-2400 program window will appear with a starter template called PERS-3600 V1.0-1 showing in the workspace. This file can be stored later, under any name, using SAVE AS... in the FILE menu (see Section 2.3).



# PURPOSE:

To provide access to each of the programs sub-menus.

The sub-menus that can be accessed from this menu are:

# File

#### NEW

To select an Account Profile template for the type of unit being programmed.

## OPEN

Loads a saved Account Profile into the RA-2400 workspace. Multiple Account Profiles can be open at the same time in the RA-2400 workspace. They can be arranged in the workspace using the Window menu on the menu bar, or by dragging them around manually.

#### CLOSE

Closes the active Account Profile. If there were any changes to the file, you will be asked if you want to save the changes.

#### SAVE

Saves the active Account Profile to the hard drive, overwriting the existing file.

#### SAVE AS...

Saves the active Account Profile while giving the option to change the name or location of the file.

#### PRINT...

Opens the PRINT window to allow printing of the active Account Profile. Resulting printout is the entire content of the Account Profile file in text format.

#### PRINT PREVIEW

Shows what will be printed on the screen with options to zoom in or print the document.

#### PRINT SETUP

Shows the printer name, paper size, orientation, and printer properties.

#### RECENT FILE LIST

Shows the last four file names (with paths) that were opened in RA-2400. Clicking on a file opens it.

#### EXIT

Closes the RA-2400 program. If any open Account Profiles have changed, you will be asked if you want to save them.

#### VIEW

#### TOOL BAR

When checked, the tool bar is displayed. NOTE: The tool bar can be turned into a re-sizable floating tool bar window by dragging it out of its docked location at the top of the workspace. The tool bar accesses many of the popular menu items. Hover the mouse pointer over the tool bar button to see a description of the button.

#### STATUS BAR

When checked, the status bar is displayed at the bottom of the workspace.

#### **COMMUNICATIONS**

#### SETUP...

Opens the Communication Setup window. Used for setting up the modem and connection type (local or remote).

#### SEND/RECEIVE...

Opens the Send/Receive window. Used for connecting to a Console to send or receive data or to det the Console's time.

#### **OPTIONS**

#### **CHANGE PASSWORD**

Opens the Change Password window. Used for changing or removing the password required to enter the RA-2400 program. THIS IS NOT THE REMOTE ACCESS PASSWORD USED TO CONNECT TO THE CONSOLE.

#### WINDOW

#### CASCADE

Arranges all open Account Profile windows layered across the workspace.

#### TILE

Arranges all open Account Profile windows next to each other in the workspace.

#### DOCUMENT LIST

Shows a list of all open Account Profiles. The check mark shows the currently active window. Click on a document to select it as the active window.

#### HELP

#### CONTENTS

Opens the help Contents search window. Used for accessing the RA-2400's built-in help file.

#### ABOUT RA-2400 REMOTE ACCESS

Displays the version number of the RA-2400 software.

# 2.4 ACCOUNT PROFILE WINDOW OVERVIEW

MENU TREE	EDIT AREA
ERS-3600 V1.0-1	
Console     Remote Audio Password     Alarms     Audio     Sensors     Communicator     Main     Routing and Numbers     Enabled Reports     4 by 2 Format     4 by 2 Point-To-Point Codes     Alarm     Trouble     Console Alarm Codes     Alarm     Trouble     Console Alarm Codes     Reminder Schedules     Reminder Schedule     2-Day Reminder Schedule     30-Day Reminder Schedule	Customer Customer ID: Name: Address 1: Address 2: Address 3: Phone 1: Phone 2: Console Phone: Notes:

# **PURPOSE:**

To enter data and make changes to an Account Profile and customize it for a specific installation.

## MENU TREE

Used for selecting the various data entry fields in the Account Profile. Clicking on the plus (+) symbols expands the branches of the menu tree. Clicking on the minus (-) symbols collapses the menu tree branch. Clicking on an item displays the data entry fields in the edit area or other information.

# EDIT AREA

Used for adding and changing the data in the Account Profile. Click on the check boxes, buttons, and enter text and numbers in the data areas to modify the Account Profile.

# 3. COMMUNICATIONS SETUP

3.1	COM PORT
3.2	<b>SPEAKER</b>
3.3	<b>CONNECTION OPTIONS</b>
3.4	MODEM INITIALIZATION STRING

Communication Setup	
Comm Port COM1 C Off Carrier C On	
Connection Options Bemote Dialing Dial Method Tone C Pulse Local Cable Connection	
Modern initialization string Use default initialization string: &FE0 S9=1 S7=60 S10=10 S12=5	
C Use custom initialization string:	

# **PURPOSE:**

The communications setup window sets the COM port for the modem, the modem's speaker characteristics, type of connection (local or remote), dialing method (tone or pulse), and modem initialization string.

- From the COMMUNICATIONS menu, select SETUP... to view the Communications Setup window.
- ◆ See Sections 3.1 3.4 and make any changes as required.
- After making any changes to the Communication Setup window, click OK to accept the changes and close the window.

СОМ6 СОМ7 СОМ8
----------------------

# **PURPOSE:**

To select which communications (COM) port the modem is connected to.

# USER RESPONSE:

- Use the drop-down menu to select the COM port number that the modem is connected to.
- NOTE: See the TESTING THE MODEM Section (1.5) of this manual for determining the proper COM port number.

# 3.2 SPEAKER

Speaker	
O Off	
<ul> <li>Carrier</li> <li>On</li> </ul>	
, on	

## **PURPOSE:**

To set how the modem's speaker functions before and during communications.

- Select OFF to silence the modem's speaker at all times.
- Select CARRIER to hear the modem connect and have the speaker silenced when the RA-2400 is connected to the Console.
- Select ON to hear the modem connect and hear the RA-2400 communicate with the Console (for testing only).

# 3.3 CONNECTION OPTIONS

Connection Options			
● <u>R</u> emote Dialing	Dial Method Tone	C Pulse	
C Local Cable Con	nection		


## **PURPOSE:**

To choose how the modem will connect to the Console.

Remote Dialing dials a telephone number with the method chosen (tone or pulse) to connect with the Console over a standard telephone line.

Local Cable Connection does not dial a telephone number, but communicates with the Console wired directly to the modem.

- Select REMOTE DIALING if the Console is going to be accessed over the telephone line.
- Select TONE or PULSE depending on the requirements for your telephone system. NOTE: This only affects Remote Dialing.
- Select LOCAL CABLE CONNECTION if the modem's LINE jack is connected directly to the Console's LINE jack (see wiring example below).



# 3.4 MODEM INITIALIZATION STRING

Modem initialization string	1
<ul> <li>Use default initialization string:</li> </ul>	
&F E0 S9=1 S7=60 S10=10 S12=5	
O Use custom initialization string:	

## **PURPOSE:**

Used to choose whether the default or a custom initialization "string" is sent to configure the modem (*a "string" is a series of characters that are commands for the modem*). Modem's use initialization strings to setup their speed, data type, and other options. The RA-2400 sends the initialization string to the modem before using the modem to connect to the Console.

NOTE: There are hundreds of models of modems available, each with unique characteristics. Instead of using the default modem string, some modems may perform better with a custom initialization string. Refer to your modem's manual.

- Leave USE DEFAULT INITIALIZATION STRING option selected unless you are having trouble connecting with your modem.
- IF YOU ARE HAVING TROUBLE CONNECTING WITH YOUR MODEM, and it tests OK with the Windows modem test diagnostics (see Section 1.5), try using a custom initialization string. Various model modems have different requirements for initialization strings. Refer to your modem's manual for the required commands to place the modem in 300 BAUD BELL 103 configuration. Two examples are "&F1&N1" and "N0S37=1". If the initialization string is incorrect, the RA-2400 will display "ERROR WRITING INITIALIZATION STRING".
- NOTE: When entering a custom initialization string, don't enter the "AT" command. The RA-2400 program will do this automatically.


# 4. CREATING A CUSTOM ACCOUNT PROFILE

4.1	<b>NEW WINDOW</b>
4.2	CUSTOMER INFORMATION
4.3	CONSOLE REMOTE AUDIO PASSWORD
4.4	CONSOLE ALARMS
4.5	CONSOLE AUDIO
4.6	SENSORS
4.7	COMMUNICATOR MAIN
4.8	COMMUNICATOR ROUTING AND NUMBERS 24
4.9	COMMUNICATOR ENABLED REPORTS
4.10	<b>COMMUNICATOR 4 BY 2 FORMAT</b>
4.10	.1 4 BY 2 POINT-TO-POINT ALARM CODES
4.10	.2 4 BY 2 POINT-TO-POINT TROUBLE CODES
4.10	.3 CONSOLE REPORT CODES
4.10	.4 4 BY 2 GENERAL ALARM CODES
4.11	ADEMCO CONTACT-ID REPORT CODES

Each Console installation requires an Account Profile. While many items are the same in different Consoles reporting to the same Central Station, some items (account number, customer information, & sensor information) are unique for each installation.

A custom Account Profile is created by editing the account profile template included with the RA-2400 software. The customized profile should then be saved with a unique name for the account and then sent to the Console.

To provide a clean start. Close any open Account Profiles on the workspace.



# **PURPOSE:**

To select an Account Profile template for the type of unit being programmed.

# **USER RESPONSE:**

# NEW

- ◆ Click on NEW icon on tool bar or select NEW from the FILE menu.
- ♦ Select PERS-3600 V1.0.
- ✦ Click OK.

The new Account Profile will appear as a starter template called PERS-3600 V1.0-1 (or -2, -3, etc.) in the workspace.

# 4.2 CUSTOMER INFORMATION

Customer     The console	Customer
· Sensors • Communicator	Customer ID: 41144
i∰- Reminder Schedules	Name: Bob Smith
	Address 1: Apt #123
	Address 2: 456 Elm Street
	Address 3: Goodtown, CA 90045
	Phone 1:
	Phone 2:
	Console Phone: 5551234
	Notes:
	Bob has a cardiac condition
	Wife (Mary) is blind

#### **PURPOSE:**

For entering customer information specific to the installation for the Account Profile.

# **USER RESPONSE:**

## **CUSTOMER**

- NOTE: All fields are optional and do not have to be filled in. This information is not sent to the Console.
- + Enter a CUSTOMER ID for the installation.
- Enter the customers name in the NAME field.
- Enter the customers address in ADDRESS fields 1, 2, & 3.
- Enter the customers telephone number(s) in PHONE fields 1 & 2.
- Enter the number of the telephone line that the Console is connected to in the CONSOLE PHONE field. This field will show as the telephone number for the account in the Send/Receive window.
- NOTE: DO NOT enter any dashes or spaces into the telephone number fields. Enter numbers only.
- Enter any special information about the customer in the NOTES field.

# 4.3 CONSOLE REMOTE AUDIO PASSWORD

41144 Bob Smith.p36     Customer     Console     Remote Audio Password     Alarms     Audio     Sensors     Communicator     Reminder Schedules	Remote Audio Password
---	-----------------------

# **PURPOSE:**

For setting the Remote Audio Communications password. This is the code a caller will need to enter using the telephone keypad to establish voice communications with the Console.

## **USER RESPONSE:**

 Enter a four-digit code in the REMOTE AUDIO PASSWORD field (the factory default code is 1234).

# MAKING A REMOTE AUDIO CALL


To establish remote audio communications with the Console:

- 1. Dial the number of the phone line that the Console is connected to, allow it to ring three times, then hang up
- 2. Wait about 10 seconds, then call the Console a second time
- 3. When the Console answers, a tone will sound for about 8 seconds
- 4. When the tone ends, enter the Remote Audio Password (default 1234) followed by the # key

The console will begin audio communications (2-way duplex, 2-way manual, or listen-only) depending on the Console's programming (see Section 4.5)

In NOTE: If the Console audio is set to "none" Remote Audio Communications will not function

# 4.4 CONSOLE ALARMS



#### PURPOSE:

For setting the way the emergency and fire sirens work. Also sets the activity timer period and the option for Console annunciation of low batteries, sensor status, and AC power failure.

#### **USER RESPONSE:**

## ALARMS

- Select SILENT to disable the emergency siren or select SIREN FOR SET TIME for a timed siren after activation. With timed siren selected, enter the length of time (from 1 to 30 minutes) for the siren to run.
- Check the SIREN ACTIVE AFTER REPORT box if you want the siren to continue after the communicator report to the Central Station is complete (does not effect the fire siren)
- Enter the length of time (in minutes) for the fire siren to run in the FIRE ALARM SIREN TIME field.

## ACTIVITY TIMER

Click the arrow to show a list of settings for the Activity Timer.

Select 8 HOURS to require the customer to press the HOME button on the Console or trigger an activity transmitter at least once in 8 hours to prevent an inactivity alarm from occurring.

Select 12 HOURS to require the customer to press the HOME button on the Console or trigger an activity transmitter at least once in 12 hours to prevent an inactivity alarm from occurring.

Select 24 HOURS to require the customer to press the HOME button on the Console or trigger an activity transmitter at least once in 24 hours to prevent an inactivity alarm from occurring.

Select DISABLED to prevent the Activity Timer from running.

# CONSOLE VOCALIZATION

- Check the ENABLE VOCALIZATION to have the Console announce (beeps or voice) Console low batteries, sensor low batteries, and sensor status exceptions.
- Use the drop-down menu to select when the Console will announce the status of its telephone line and AC power connections.

Select ONCE ON STATUS CHANGE to have the Console announce phone line trouble or AC power failure once when the condition occurs.

Select **ON STATUS CHANGE AND HOURLY WHEN BAD** to have the Console announce phone line trouble or AC power failure when the condition occurs and every hour thereafter.

Select OFF to disable Console vocalization for phone line trouble and AC power failure.

# 4.5 CONSOLE AUDIO

🚟 41144 Bob Smith.p36	
Customer	Audio
Remote Audio Password	Two-way audio:
Audio	Two-way duplex
Sensors	Speaker phone:
Communicator	Speaker phone disabled
Reminder Schedules	Voice Prompts Enabled

#### **PURPOSE:**

Selects how the Console audio operates. Audio modes for monitoring with the Console's built-in microphone and communicating through the speaker to the customer are selectable. The voice prompts from the Console can be enabled or disabled.

With 2-way Audio enabled, after the Central Station operator acknowledges the communicators report, the Console will stop its siren and switch to the selected audio mode for 90 seconds.

# **USER RESPONSE:**

#### TWO-WAY AUDIO

Click the arrow to show a list of settings for Two-way Audio and select the desired mode.
 NONE (All sensors): Console will not report as an audio account to the Central Station. No audio monitoring will occur.

LISTEN ONLY: The operator will be able to hear sound from the Console but will not be able to talk through the Console's speaker. Pressing "9" on a telephone connected to the line disconnects the call (press any key but "9" to extend the time 90 seconds).

TWO-WAY MANUAL: The operator will be able to hear sound from the Console and will be able to talk through the Console's speaker. The operator can switch from listen to talk by pressing "1", or switch from talk to listen by pressing "3" on a telephone connected to the line. Pressing "9" disconnects the call (press any key but "9" to extend the time 90 seconds).

TWO-WAY DUPLEX: The operator will be able to hear sound from the Console and will be able to talk through the Console's speaker. The Console will listen until the operator speaks, then the voice activation will switch the Console to talk as long as the operator speaks. The operator can still switch from listen to talk manually by pressing "1", or switch from talk to listen by pressing "3" on a telephone connected to the line (with increased volume). Pressing "6" returns to two-way duplex. Pressing "9" disconnects the call. Press any key but "9" to extend the time 90 seconds.

## SPEAKER PHONE

Click the arrow to show a list of settings for Speaker phone and select the desired mode.
 SPEAKER PHONE DISABLED: Speaker phone feature will not be available.

SPEAKER PHONE ENABLED (15 MINUTES): The communication link will be automatically disconnected after 15 minutes, even if a call is in progress.

SPEAKER PHONE ENABLED (30 MINUTES): The communication link will be automatically disconnected after 30 minutes, even if a call is in progress.

SPEAKER PHONE ENABLED (60 MINUTES): The communication link will be automatically disconnected after 60 minutes, even if a call is in progress.

 Check the VOICE PROMPTS ENABLED box to have the Console announce system events with a digitally synthesized human voice.

Console Sensors Sensors 2 Sensor 2 Sensor 3 Sensor 4 Sensor 5 Sensor 5 Sensor 6 Sensor 7 Sensor 8 Sensor 9 Sensor 10 Sensor 11 Sensor 12 Sensor 13 Sensor 13 Sensor 14 Sensor 15 Sensor 14 Sensor 16 Communicator Reminder Schedules	Sensor Type Not Installed  Delayed Alam Setting  Disabled  Sensor Options  Auto restore  Supervised  Silent alam  Troc-way voice activation  Sensor Status  Low Battery  Trocble	Sensor Rules Delayed Alam Setting This function is ignored for Fire and Activity Reset sensors. Silent Alam Checking this box will not cause Fire or Activity Reset sensors to be silent. Two-way voice activation Checking this box will not enable Two-way audio if None (Al Sensors) is selected in the CONSOLE:AUDIO screen.
--	---	--

# **PURPOSE:**

To display and edit sensors installed in the Console's memory. Up to 16 sensors may be installed, each with its own type, restore and supervision options. The status of the sensor selected is also displayed.

NOTE: To display and edit sensors installed in the Console, the sensor data must first be received from the Console (see Section 6.7).

# **USER RESPONSE:**

# SENSOR TYPE

- Click on the sensor number in the menu tree to view it.
- View or edit the SENSOR TYPE. The sensor type options are:

**NOT INSTALLED:** No sensor has been stored in this sensor location. Also can be used to remove a sensor from the Console's memory. Sensors cannot be added with this menu.

FIRE: Sensor will trigger the fire siren and report the fire code to the Central Station.

ACTIVITY RESET: Sensor will reset the Activity Timer, preventing an inactivity report.

**EMERGENCY (1 BUTTON):** Sensor is a one-button transmitter that will trigger the emergency siren and report the emergency code to the Central Station. **NOTE: MODEL DXS-63 TWO-BUTTON TRANSMITTERS ARE SINGLE-CHANNEL DEVICES AND SHOULD BE SET TO THIS OPTION.** 

**EMERGENCY (2 BUTTON):** Sensor is a two-button transmitter. Both buttons must be pressed to trigger the emergency siren and report the emergency code to the Central Station.

# 4.6 SENSORS (CONTINUED)

E Console     Sensor s     Sensor s     Sensor 1     Sensor 3     Sensor 3     Sensor 4     Sensor 5     Sensor 6     Sensor 6     Sensor 7     Sensor 8     Sensor 9     Sensor 10     Sensor 11     Sensor 11     Sensor 13     Sensor 14     Sensor 16     Eommunicator     Reminder Schedules	Sensor Type Not Installed  Delayed Alarm Setting  Disabled  Sensor Options  Auto restore  Supervised  Silent alarm  Towoway voice activation  Sensor Status  Low B attery  Trouble	Delayed Alam Setting This function is ignored for Fire and Activity Reset sensors. Silent Alam Checking this box will not cause Fire or Activity Reset sensors to be silent. Two-way voice activation Checking this box will not enable Two-way audio if None (Al Sensors) is selected in the CONSOLE::AUDIO screen.
---	---	---

# DELAYED ALARM SETTING

- Click on the sensor number in the menu tree to view it.
- View or edit the DELAYED ALARM SETTING. The delayed alarm settings are: DISABLED: An alarm transmission received from the selected sensor will not be delayed.
   15 MINUTE DELAY: An alarm transmission received from the selected sensor will be delayed for 15 minutes.
   30 MINUTE DELAY: An alarm transmission received from the selected sensor will be delayed for 30 minutes.
- NOTE: If a transmitter restore is received prior to the timeout period, then the alarm will be automatically cancelled and the unit will return to normal standby operation. The Delayed Alarm Setting is ignored for Fire and Activity Reset sensors.

## SENSOR OPTIONS

View or edit the SENSOR OPTIONS. These options are automatically set when the sensor is programmed into the Console. The sensor options are:

AUTO RESTORE: This box should be checked for all model sensors except the Model DXS-31.

SUPERVISED: This box should be checked for all sensors that send periodic status reports. DXT sensors do not send periodic status reports. REMOVE THE CHECK FROM THIS BOX IF A MODEL DXT SENSOR HAS BEEN PROGRAMMED INTO THIS SENSOR LOCATION or if you don't want supervision for a DXS sensor. This will keep the Console STATUS indicator from lighting due to missing status reports.

 NOTE: The sensor can still report a low battery condition (see Section 4.9) this will cause the Console's STATUS indicator to flash.

SILENT ALARM: This box should be checked for all sensors that need to be silent locally. Fire or Activity Reset sensors will not be silent.

TWO-WAY VOICE ACTIVATION: This box should be checked for all sensors that require two-way voice activation. Checking this box will not enable Two-way audio if NONE is selected in the **CONSOLE AUDIO** screen (see Section 4.5).

# SENSOR STATUS

 View the SENSOR STATUS to see the condition of the sensor selected. The sensor status conditions are:

LOW BATTERY: The sensor has sent a low battery signal to the Console. Replace the sensor's battery.

**TROUBLE:** The Console has not received a status report from this sensor in 24 hours. Sensor may have been out of range of the Console's receiver, or the sensor may be non-functional.

 NOTE: After any changes are made to the sensor type or sensor options, test the sensor to verify proper operation.

# 4.7 COMMUNICATOR MAIN

🚟 41144 Bob Smith.p36	
Customer Console Sensors Communicator Routing and Numbers Enabled Reports 4 by 2 Format - 4 by 2 Point-To-Point Codes - Alarm - Trouble Console Alarm Codes - 4 by 2 General Alarm Codes - 8 bit 2 Console Statement Codes - 9 bit 2 Code Statement Code Statement Codes - 9 bit 2 Code Statement Code Stat	Communicator Main

## PURPOSE:

For configuring the Console's communicator format, dialing method, remote access password, dialing delay, and auto answer options.

## **USER RESPONSE:**

## COMMUNICATOR MAIN

- Check the ON box to enable the communicator in the Console.
- NOTE: You may want to turn the communicator off while testing the system to prevent the Console from trying to dial out when it is not connected to a telephone line.
- FORMAT: Select either 4 BY 2 or ADEMCO CONTACT ID for the communicator format depending on the Central Station's requirements.
- DIAL METHOD: Select either TONE or PULSE dialing for the Console.
- ◆ REMOTE ACCESS PASSWORD: Enter a six-digit password. This is the password required to connect to the Console with the RA-2400 program. The default password is "987654". DO NOT FORGET THIS PASSWORD, LOCAL OR REMOTE PROGRAMMING ACCESS TO THE CONSOLE IS IMPOSSIBLE WITHOUT IT.
- 15 SECOND DIALING DELAY: Check this box to cause a 15 second delay before the communicator starts to dial after an alarm. This gives the subscriber time to cancel a Central Station report before the unit dials out.
- CONSOLE AUDIBLE DIALING TONES: Check this box to have the Console's speaker monitor the telephone line when a call is placed. The telephone system's dial tone and the Console's DTMF dialing tones will sound from the speaker. This option is generally used for system testing or troubleshooting and should be disabled during normal use.
- PREVENT CONSOLE FROM ANSWERING THE PHONE: Check this box to disable the Console's telephone ring detection feature. This keeps the Console from automatically answering the phone. Even if this box is checked, the Console can still be programmed by placing the Console into Test Mode and forcing the Console to answer by pressing the Console's HELP button while the phone is ringing (see Section 3.3, Local Cable Connection).

# 4.8 COMMUNICATOR ROUTING AND NUMBERS

🚟 41144 Bob Smith.p36	
Customer Console Sensors Communicator Hain Routing and Numbers Enabled Reports 4 by 2 Format 4 by 2 Point-To-Point Codes 4 alarm Trouble Console Alarm Codes 4 by 2 General Alarm Codes Reminder Schedules	Routing and Numbers         Ademoc Contact ID:         [2376]         4 by 2:         [2376]         Trouble Report Routing         Trouble Report Routing         Trouble Reports to Primary and Secondary         Trouble Reports only to Supervisory         Phone Numbers         Primary:         18005551587         Secondary:         18005551588         Supervisory:

## **PURPOSE:**

For configuring the Console's communicator account number, trouble report routing, and telephone numbers.

# **USER RESPONSE:**

#### **ACCOUNT NUMBERS**

• Enter a four digit account number for the communicator format used.

## TROUBLE REPORT ROUTING

- Select TROUBLE REPORTS TO PRIMARY AND SECONDARY to have trouble reports routed to the primary number for five attempts, then to the secondary number for five attempts before re-trying. Select TROUBLE REPORTS ONLY TO SUPERVISORY to have trouble reports routed to the supervisory number only.
- NOTE: This does not effect emergency reports which are always routed to the primary or secondary telephone numbers.

#### PHONE NUMBERS

- Telephone numbers can be up to 20 digits long. DO NOT enter any dashes or spaces into the telephone number fields. The "#" symbol inserts a 1-second delay, the "~" symbol inserts a 5-second delay.
- NOTE: If no telephone numbers are entered, the Console will not report.
- PRIMARY: Enter the correct telephone number to connect the Central Station receiver.
- SECONDARY: Enter the correct backup telephone number to connect the Central Station receiver.
- SUPERVISORY: For trouble reports: Enter the correct telephone number to connect the Central Station receiver for supervisory reports.

# 4.9 COMMUNICATOR ENABLED REPORTS

Customer Console Sensors Communicator Main Routing and Numbers Enabled Reports 4 by 2 Format 4 by 2 Format 4 by 2 Pornt-To-Point Codes Alarm Trouble Console Alarm Codes 4 by 2 General Alarm Codes Reminder Schedules	Enabled Reports
--	-----------------

# **PURPOSE:**

For configuring the Console condition reporting options.

# **USER RESPONSE:**


# **ENABLED REPORTS**

- Check the ALL TROUBLE REPORTING box to have the Console's communicator send all status reports to the central station. These include the Console low battery, sensor supervisory, sensor low battery, and when the Activity Timer is turned on or off.
- Check AC POWER FAIL STATUS REPORTING if communication of loss and restoration of AC power is desired.

## AUTOMATIC TEST REPORT

- Click arrow on AUTOMATIC TEST REPORT INTERVAL and select 1, 7, 30 days or disabled for the Console automatic test report.
- NOTE: The first 30-day status report will occur 30 days plus 12 hours from the time the Console is programmed.
- Check the FULLY AUTOMATIC SYSTEM TEST box to have test reports occur at the set interval only when all Console conditions are OK. If any sensor has a supervisory condition, or the Console has any form of trouble (low backup battery, no AC) the test report will **not** be sent.

# 4.10 COMMUNICATOR 4 BY 2 FORMAT



NOTE: Section 4.10 pertains to the 4 by 2 communicator format only.

# **PURPOSE:**

For configuring how the 4 by 2 format will report to the Central Station. General reporting *or* Point-to-Point reporting methods are available for the 4 by 2 format.

**POINT-TO-POINT REPORTING:** Point-to-Point reporting sends each sensor/ zone number with a unique **ALARM** code and **TROUBLE** code.

**GENERAL REPORTING:** General reporting can send three report codes for sensors: **FIRE**, **EMERGENCY**, and **TROUBLE**. General reporting does not indicate which sensor caused the report.

NOTE: With either reporting method, the Console report codes are the same (see Section 4.10.3).

# USER RESPONSE:

# 4 BY 2 FORMAT

- Select POINT-TO-POINT to have the Console's communicator send 4 by 2 Point-to-Point report codes.
- Select GENERAL to have the Console's communicator send only the three 4 by 2 General report codes.

# 4.10.1 4 BY 2 POINT-TO-POINT ALARM CODES

Customer Console Sensors Communicator Main Routing and Numbers Enabled Reports 4 by 2 Format A by 2 Point-D-Point Codes Alarm Trouble Console Alarm Codes H by 2 General Alarm Codes Reminder Schedules
---

# **PURPOSE:**

To view and edit the 16 sensor (zone) alarm report codes.

NOTE: 4 by 2 Point-to-Point Reporting must be selected (see Section 4.10) for these codes to report.

# **USER RESPONSE:**

# **ZONE CODES**

- Enter a new two-digit alarm code for any sensor (zone) that needs to be changed.
- NOTE: Entering a "0" for an alarm code will prevent that sensor from reporting alarms.

# 4.10.2 4 BY 2 POINT-TO-POINT TROUBLE CODES

41144 Bob Smith.p36     Customer     Console     Sensors     Communicator     Main     Routing and Numbers     Enabled Reports     41 by 2 Point-To-Point Codes     Aiarm     Trouble     Console Alarm Codes     4 by 2 General Alarm Codes     Aby Codes     Aby Codes     Aby Codes     Aby Codes     Alarm Codes     Aby Codes     Aby Codes     Alarm Codes     Aby Codes     Aby Codes     Aby Codes     Alarm Codes     Aby Codes     Aby Codes     Codes     Aby Codes     Codes     Aby Codes	Lange     Lange       1:     41     9:     49       2:     42     10:     50       3:     43     11:     51       4:     44     12:     52       5:     45     13:     53       6:     46     14:     54       7:     47     15:     55       8:     48     16:     56
--	--

## **PURPOSE:**

To view and edit the 16 sensor (zone) trouble report codes.

NOTE: 4 by 2 Point-to-Point Reporting must be selected (see Section 4.10) for these codes to report.

# USER RESPONSE:

# ZONE CODES

- Enter a new two-digit trouble code for any sensor (zone) that needs to be changed.
- NOTE: Entering a "0" for a trouble code will prevent that sensor from reporting trouble.

# 4.10.3 CONSOLE REPORT CODES

Altitude Bob Smith.p36      Customer      Console     Access Code     Adams     Audo     Sensors     Communicator     Main     Roucing and Numbers     Enabled Reports     Hold Reports     Audo     Audo     Audo     Audo     Audo     Access Code     Adams     Audo     Sensors     Communicator     Adam     Touble     Audo     Audo	Console Report Codes Emergency Alarm: 53 Cancet: 70 Battery Restore: 71 No AC: 72 Low Battery: 73 AC Restoral: 34 Inactivity Alarm: 90 Activity Ort: 91 Activity Ort: 92 Automatic Test: 93 Reminder Timeout: 96 NDTE: PERS:2400 versions 1.0 to 1.4 do not support "No AC" and "AC Restoral" reporting.
--	---

# **PURPOSE:**

To view and edit the Console report codes. These codes are sent for Console events such as the Console's HELP button, inactivity alarm, Console low battery and battery restore, no AC and AC restoral. Activity On & Off reports occur when the Console's activity timer is turned on or off. The cancel report occurs when the Console's CANCEL button is pressed during an alarm. The Automatic Test Report occurs every 1, 7, or 30 days if the Automatic Test Report is enabled (see Section 4.9).

NOTE: These report codes are sent for both 4 by 2 General and 4 by 2 Point-by-Point Reporting.

## **USER RESPONSE:**

# **CONSOLE REPORT CODES**

- Enter a new two-digit report code for any Console event that needs to be changed.
- NOTE: Entering a "0" for a report code will prevent that event from reporting.

<ul> <li>41144 Bob Smith.p36</li> <li>Customer</li> <li>Console</li> <li>Sensors</li> <li>Communicator</li> <li>Main</li> <li>Routing and Numbers</li> <li>Enabled Reports</li> <li>4 by 2 Format</li> <li>4 by 2 Point-To-Point Codes</li> <li>4 by 2 General Alarm Codes</li> <li>Reminder Schedules</li> </ul>	4 by 2 General Alarm Codes Fire: 1 Emergency: 2 Trouble: 6
---	---

# **PURPOSE:**

To view and edit the two general alarm codes and the general trouble code.

INSTE: 4 by 2 General Reporting must be selected (see Section 4.10) for these codes to report.

# USER RESPONSE:

# 4 BY 2 GENERAL ALARM CODES

- Enter a new one or two-digit report code for any general alarm code that needs to be changed.
- NOTE: Entering a "0" for an alarm code will prevent that event from reporting.

# 4.11 ADEMCO CONTACT-ID REPORT CODES

The Ademco Contact-ID reporting codes are pre-defined and cannot be changed. These reporting codes are provided as reference. The Ademco Contact-ID extended report codes indicate the sensor number that triggered the event. Console events report with a "000" extended code.

ADEMCO CONTACT-ID REPORT CODES				
EVENT	ALARM CODE	EXTENDED CODE		
CONSOLE EMERGENCY	E100	018		
SENSOR EMERGENCY	E101	0xx		
SENSOR FIRE	E111	0xx		
CANCEL	E406	000		
SENSOR LOW BATTERY	E384	0xx		
SENSOR STATUS TROUBLE	E381	0xx		
CONSOLE LOW BATTERY	E302	000		
CONSOLE BATTERY RESTORE	R302	000		
INACTIVITY ALARM	E102	000		
ACTIVITY ON	E372	000		
ACTIVITY OFF	E371	000		
1, 7, OR 30-DAY STATUS	E602	000		
2-WAY AUDIO	E606	000		
CONSOLE NO AC	E301	000		
CONSOLE AC RESTORAL	R301	000		
REMINDER TIMEOUT	E356	000		
xx = SENSOR NUMB	ER IN EXTENDED REPO	RT		

NOTE: Ademco Contact-ID Reporting must be selected for these codes to report (see Section 4.10).

# 5. REMINDER MESSAGES

5.1	REMINDER SCHEDULE SETUP	33
5.2	1-DAY REMINDER SCHEDULE	34
5.3	2-DAY REMINDER SCHEDULE	35
5.4	7-DAY REMINDER SCHEDULE	36
5.5	30-DAY REMINDER SCHEDULE	37
As	a special feature, the PERS-3600 Console can record and pl	ay
up	to approximately eight 15-second audio reminder messages. T	he
ron	ninder messages can be used to help the subseriber remember	to

reminder messages can be used to help the subscriber remember to take medications, call someone, get ready for an appointment, etc. Each message is controlled by a real time clock and can be programmed via the RA-2400 software to play daily, every other day, weekly, or monthly.

# NOTE: The Reminder Message audio can only be recorded locally at the Console. Reminder Message audio CANNOT be recorded over the telephone.

Reminder messages are played and repeated in three-minute intervals for either 15 or 30 minutes (programmable) until acknowledged by pressing the **CANCEL** button. If a Reminder Message is not acknowledged, the Console can report the event to the Central Station and trigger 2-way audio communication if programmed to do so.

Reminder Messages can also be programmed for single-play. After playing the message, the Console will sound a beep every three seconds until the message is acknowledged or the Reminder Message timeout period expires.

# 5.1 REMINDER SCHEDULE SETUP

# Console # Sensors # Communicator ■ Reminder Schedules <u>Terminder Schedule Settings</u> 1-Day Reminder Schedule - 2-Day Reminder Schedule - 30-Day Reminder Schedule	Reminder Schedule Settings          Reminder Timeout Interval         Image: The set schedules to today         Do not replay reminder message during timeout interval         Image: Do not report reminder timeout	This one-time setting will not be saved.
	Console DST	This read-only setting follows the Console DST Auto Adjust on the SEND/RECEIVE communication panel.

## **PURPOSE:**

To set the options for the Console's Reminder Message feature.

## **USER RESPONSE:**

# REMINDER TIMEOUT INTERVAL

- Select 15 MINUTES to have the Console repeat the reminder message every three minutes for 15 minutes, or until acknowledged by pressing the CANCEL button.
- Select 30 MINUTES to have the Console repeat the reminder message every three minutes for 30 minutes, or until acknowledged by pressing the CANCEL button.

## **REMINDER SCHEDULE SETTINGS**

 RESET SCHEDULES TO TODAY: Check this box to have the Reminder Message day timer start from when the Account Profile is sent to the Console.
 DO NOT check this box if the Reminder Message day tir

DO NOT check this box if the Reminder Message day timer in the Console was set previously and is not desired to be changed.

- NOTE: Checking the RESET SCHEDULES TO TODAY box only affects the 2, 7, and 30-day Reminder Messages.
- ◆ DO NOT REPLAY REMINDER MESSAGES DURING TIMEOUT INTERVAL: Check this box to cause Reminder Messages to play only once and not be repeated every three minutes. After the message is played, the Console will sound a beep every three seconds until the message is acknowledged or the Reminder Message timeout period expires.
- DO NOT REPORT REMINDER TIMEOUT: Check this box to disable Reminder Message timeout reporting to the Central Station if a reminder message is not acknowledged by pressing the CANCEL button before the reminder timeout interval expires.

# 5.2 1-DAY REMINDER SCHEDULE

🚟 41144 Bob Smith.p36	
<ul> <li>⊂ Customer</li> <li>⊕ Console</li> <li>⊕ Sensors</li> <li>⊕ Communicator</li> <li>⊨ Remininder Schedules</li> <li>⊨ Remininder Schedule</li> <li>≥ Day Reminder Schedule</li> <li>⇒ 2-Day Reminder Schedule</li> <li>⇒ 3-Day Reminder Schedule</li> <li>&gt; 30-Day Reminder Schedule</li> </ul>	1-Day Reminder Schedule         Hour : Minute : Message           0-23         : D53         : 1-8           1st Reminder:         09:00:1         2           2nd Reminder:         12:15:2         3           3rd Reminder:         15:00:1         4           4th Reminder:         18:00:3         5           5th Reminder:         1         5           7th Reminder:         1         3           8th Reminder:         1         3

## **PURPOSE:**

To set the times that Reminder Messages on a 1-day schedule will be played. Up to eight play times can be programmed for messages that will play every day. One of the eight recorded Reminder Messages can be selected for each of the eight play times.

# USER RESPONSE:

## **1-DAY REMINDER SCHEDULE**

Use the following format to enter the message play times:

## HOUR:MINUTE:MESSAGE

Place a colon (:) between each entry.

 Enter the time and message number to play for up to eight messages.

**HOUR:** Enter the hour number in 24-hour military time format (hour 0-23) for the message to play.

MINUTE: Enter the minute (minute 0-59) for the message to play.

**MESSAGE:** Enter the number of the Reminder Message to play. The message numbers are announced by the Console when the messages are recorded.

IP: To convert 12-hour time to 24-hour time, add 12 to the hour for 1pm and later, up to midnight.

# 5.3 2-DAY REMINDER SCHEDULE

🚟 411 44 Bob Smith.p36	
Cutsoner     Console     Sensors     Communicator     Reminder Schedules     Reminder Schedule Settings     T-Day Reminder Schedule     COby Reminder Schedule     So-Day Reminder Schedule     So-Day Reminder Schedule	2-Day Reminder Schedule         Day : Hou:: Mirute : Message         1:z: 0:23 : 0:53 : 1:8         1:st Reminder:         2nd Reminder:         21:2002         3rd Reminder:         4th Reminder:         5th Reminder:         6th Reminder:         7th Reminder:         8th Reminder:         Schedule Day:         1

### **PURPOSE:**

To set the times that Reminder Messages on a 2-day schedule will be played. Up to eight play times can be programmed for messages that will play every other day. One of the eight recorded Reminder Messages can be selected for each of the eight play times.

# **USER RESPONSE:**

### 2-DAY REMINDER SCHEDULE

Use the following format to enter the message play times:

#### DAY:HOUR:MINUTE:MESSAGE

Place a colon (:) between each entry.

- Enter the starting day, the time, and message number to play for up to eight messages.
   DAY: Enter 1 or 2 for the Console's schedule day for the message to play on.
- NOTE: The Console's current day will be displayed in the SCHEDULE DAY area after receiving data from the Console. To set the Console's schedule day without receiving data from the Console, the Console's schedule day can be reset to 1 using the RESET SCHEDULE TO TODAY function (see Section 5.1).

**HOUR:** Enter the hour number in 24-hour military time format (hour 0-23) for the message to play.

MINUTE: Enter the minute (minute 0-59) for the message to play.

**MESSAGE:** Enter the number of the Reminder Message to play. The message numbers are announced by the Console when the messages are recorded.

IP: To convert 12-hour time to 24-hour time, add 12 to the hour for 1pm and later, up to midnight.

# 5.4 7-DAY REMINDER SCHEDULE

🚟 41144 Bob Smith.p36	
<ul> <li>Customer</li> <li>Console</li> <li>Sensors</li> <li>Communicator</li> <li>Reminder Schedule</li> <li>Reminder Schedule Settings</li> <li>1-Dav Reminder Schedule</li> <li>2-Dav Reminder Schedule</li> <li>30-Dav Reminder Schedule</li> </ul>	7-Day Reminder Schedule           Day : Hour : Minute : Message           1.7 : 0.23 : 0.55 : 1.8           1 st Reminder:           1 st Reminder:           5 9: 00.1           3rd Reminder:           7.12:00.2           4th Reminder:           Sth Reminder:           9th Reminder:           Sth Reminder:           1

#### **PURPOSE:**

To set the times that Reminder Messages on a 7-day schedule will be played. Up to eight play times can be programmed for messages that will play every seventh day. One of the eight recorded Reminder Messages can be selected for each of the eight play times.

# USER RESPONSE:

#### 7-DAY REMINDER SCHEDULE

Use the following format to enter the message play times:

#### DAY:HOUR:MINUTE:MESSAGE

Place a colon (:) between each entry.

 Enter the starting day, the time, and message number to play for up to eight messages.

DAY: Enter 1-7 for the Console's schedule day for the message to play on.

NOTE: The Console's current day will be displayed in the SCHEDULE DAY area after receiving data from the Console. To set the Console's schedule day without receiving data from the Console, the Console's schedule day can be reset to 1 using the RESET SCHEDULE TO TODAY function (see Section 5.1).

**HOUR:** Enter the hour number in 24-hour military time format (hour 0-23) for the message to play.

MINUTE: Enter the minute (minute 0-59) for the message to play.

**MESSAGE:** Enter the number of the Reminder Message to play. The message numbers are announced by the Console when the messages are recorded.

TIP: To convert 12-hour time to 24-hour time, add 12 to the hour for 1pm and later, up to midnight.

# **30-DAY REMINDER SCHEDULE**

🔛 41144 Bob Smith.p36	
<ul> <li>Customer</li> <li>Console</li> <li>Sensors</li> <li>Communicator</li> <li>Reminder Schedules</li> <li>Reminder Schedule Settings</li> <li>1-0xy Reminder Schedule</li> <li>2-0xy Reminder Schedule</li> <li>30-bay Reminder Schedule</li> </ul>	30-Day Reminder Schedule           Day: Hour: Minute : Message           1-30: 0-23: 0-55: 1-8           1-8           1-8           1-8           1-8           1-8           1-8           1-9           2nd Reminder:           212:00-2           3rd Reminder:           7:12:00-2           4th Reminder:           5th Reminder:           6th Reminder:           7th Reminder:           8th Reminder:           9th Reminder:           1           1

### **PURPOSE:**

5.5

To set the times that Reminder Messages on a 30-day schedule will be played. Up to eight play times can be programmed for messages that will play every seventh day. One of the eight recorded Reminder Messages can be selected for each of the eight play times.

# **USER RESPONSE:**

### **30-DAY REMINDER SCHEDULE**

Use the following format to enter the message play times:

#### DAY:HOUR:MINUTE:MESSAGE

Place a colon (:) between each entry.

- Enter the starting day, the time, and message number to play for up to eight messages.
   DAY: Enter 1-30 for the Console's schedule day for the message to play on.
- NOTE: The Console's current day will be displayed in the SCHEDULE DAY area after receiving data from the Console. To set the Console's schedule day without receiving data from the Console, the Console's schedule day can be reset to 1 using the RESET SCHEDULE TO TODAY function (see Section 5.1).

**HOUR:** Enter the hour number in 24-hour military time format (hour 0-23) for the message to play.


MINUTE: Enter the minute (minute 0-59) for the message to play.

**MESSAGE:** Enter the number of the Reminder Message to play. The message numbers are announced by the Console when the messages are recorded.

IP: To convert 12-hour time to 24-hour time, add 12 to the hour for 1pm and later, up to midnight.

# 6. SENDING AND RECEIVING CONSOLE DATA

6.1	<b>ACCESSING THE SEND/RECEIVE WINDOW</b>
6.2	CHOOSING AN ACCOUNT PROFILE
6.3	CONNECTING TO A CONSOLE
6.4	TURNING THE ACTIVITY TIMER ON & OFF
6.5	<b>SETTING THE CONSOLE'S CLOCK</b>
6.6	<b>SENDING DATA</b>
6.7	<b>RECEIVING DATA</b>
6.8	<b>DISCONNECTING FROM THE CONSOLE</b>
6.9	CLOSING RA-2400
inpo you The RA- to, c diali	ding and receiving the Account Profile data to the Console is an ortant function of the RA-2400 program. The Account Profiles that create exist only on your computer until they are copied to a Console. Send/Receive window controls all external communications for the 2400 software. It is used to select which Account Profile gets sent or received from, a Console in the field (accessed through remote ng) or connected directly to the modem (accessed through a local le connection). See Section 3.3 for connection details.



#### **PURPOSE:**

6.1

For entering data required to connect to a Console and to control the connection. Monitors the status of the communication between the RA-2400 and the Console. Allows setting the Activity Timer in the Console to ON or OFF.

# **USER RESPONSE:**

- An Account Profile file must be open before the Send/ Receive window can be accessed. Use the OPEN... or NEW command in the FILE menu or on the tool bar to load an Account Profile into the workspace.
- From the COMMUNICATIONS menu, choose SEND/RECEIVE..., or click on the SEND/RECEIVE button on the tool bar.
- NOTE: If you are opening a template created by RA-2400 Versions 1.0 to 1.7 you may get a dialog box saying that RA-2400 has detected an older version template. Click YES and RA-2400 will convert the template to the current format and it will appear on your desktop ready for use. The old template will be saved as a backup file in its original format.

# 6.2 CHOOSING AN ACCOUNT PROFILE

Send / Receive	I
CHOOSE ACCOUNT PROFILE Controle Time. Event Log Controle DST auto adjust. If Local Ime: Daylight Savings Time: Automatic DST adjust ON	

### **PURPOSE:**

For selecting which Account Profile open in the workspace will be used when connecting to a Console. The Account Profile selected automatically fills in the Console's Phone Number and Password Fields using information already entered in the profile (see Section 4.2).

### USER RESPONSE:

# CHOOSE AN ACCOUNT

- Click on the desired Account Profile in the Choose an Account box for the Console that is going to be programmed. The installation telephone number and Console password will appear in the boxes.
- NOTE: ARMING MODE will change to ACTIVITY TIMER after a PERS Account Profile is selected.

# 6.3 CONNECTING TO A CONSOLE

Send / Receive		
Phone number: 5551234	Connect Uisconnect	BUTTON
Password: 987654	Send data to console	
Choose an account: 41144 Bob Smith.p36	Beceive data from console Activity Timer	
	C Off C On	
Console Power AC: OK Batt: OK	Refresh Comm setup	
Communication Status Not connected		
Console Time, Event Log		
Check time Updat	e time Get events	
line affect	Console DST auto adjust: 🔽	
Local time: Daylight Savings Time: Auto	matic DST adjust ON	
Close	Stop	

### **PURPOSE:**

Causes the RA-2400 to connect to the Console. The RA-2400 will try to connect to the Console either locally or remotely, depending on the Communications Setup (see Section 3.3).

NOTE: The Communications Setup can be reviewed by pressing the COMM SETUP... button in the Send/Receive window.

#### **USER RESPONSE:**

NOTE: Before connecting to a Console, it is recommended that all of the sensors used in the system be entered into the Console's memory. This will prevent having to connect to the Console again after programming if modification of the sensor options is required.

#### **BEFORE CONNECTING**

- Be sure the computer's modem is powered on, connected, and tested as described in Section 1.5 of this manual.
- Check that the Console is powered on (the Console must be connected to AC power).
- Be sure that the Account Profile you want to associate with the particular Console is selected in the Choose an Account box.

# 6.3 CONNECTING TO A CONSOLE (CONTINUED)

#### **CONNECTING LOCALLY**

- Verify that the modem's LINE jack is connected to the Console's LINE jack with a double-ended modular telephone cable.
- Verify that the Console is in Test Mode.
- Click the CONNECT button. The Communication Status area will show the progress of the connection. WAIT UNTIL THE TIMEOUT TIMER BEGINS TO COUNT DOWN BEFORE PROCEEDING.
- As the timeout timer counts down, PRESS THE HELP BUTTON ON THE CONSOLE.

#### **CONNECTING REMOTELY**

- Be sure that the modem's LINE jack is connected to a working telephone line.
- Verify that the Console's LINE jack is connected to a working telephone line.
- Click the CONNECT button. The Communications Status area will show the progress of the connection. WAIT FOR THE CONNECTION TO COMPLETE. The RA-2400 will dial the number once, wait for a few rings, hang-up, then dial a second time. The Console should answer the telephone immediately when the telephone rings during the second dialing attempt.

After connecting the **Communications Status** area will show the progress of the on-line connection, then display "Connected" and the Console's version number.

The **Console Power** area will show the status of the Console's AC power and backup battery. Pressing the **REFRESH** button will update the displayed information.

Pomoto Connection in Prograce

Send / Receive	Send / Receive	
Phone Number: 5551234 Connect Disconnect	Phone Number: 5551234	Connect Disconnect
Password: Send data to console	Password: 987654	Send date to console
Choose an account: 41144 Bob Smith p20 C Off C On	Choose an account 41144 Bob Smith p20	Receive data from console Activity Timer C Off C On
Console Power AC: OK Bott: OK Refresh Comm Setup	Console Power AC: OK Batt: OK	Refresh Comm Setup
Communication status Connect by precising the emergency/help button while in test mode. Timeout in 47 sec	Communication status Not connected Dialing the first time	
Console Time: Event Log Deck time: Console Time: Hours offset friom local:	Console Time, Event Log Check time Console time House offset House offset	te time Get events DST auto adjust
Local time: Daylight Savings Time: Automatic DST adjust ON Clove Stop	Local time: Daylight Savings Time: Auto Close	matic DST adjust ON

#### Local Connection in Progress

TURNING THE ACTIVITY TIMER ON & OFF

Send / Receive	
Phone Number: 5551234 Password SeroE4 Beceive data to console Beceive data from console Choose an account: 1144 Bets Smith p20 Console Power AC: DK Batt: DK Befresh Communication status Connected Personal Emergency System 3600, Ver10	ACTIVITY TIMER BUTTONS
Console Time, Event Log Check Time Update Time Get Events Console time: Hour offset D Console DST auto adjust 17 Local time: Daylight Savings Time: Automatic DST adjust DN Close Stop	

### **PURPOSE:**

6.4

Turns the Consoles Activity Timer ON and OFF. When the Consoles Activity Timer is on the emergency alarm will trigger automatically if the time set elapses before an activity transmitter is triggered or the Console's HOME button is pressed.

The Activity Timer can be set for 8, 12 or 24 hour operation (See Section 4.4).

# **USER RESPONSE:**

### ACTIVITY TIMER

- Click the ON button in the ACTIVITY TIMER area to turn the Console's Activity Timer on.
- Click the OFF button in the ACTIVITY TIMER area to turn the Console's Activity Timer off.

### **SPECIAL NOTES:**

The Activity Timer setting will be transferred to the Console immediately as long as the RA-2400 is connected to the Console.

# 6.5 SETTING THE CONSOLE'S CLOCK

	Send / Receive		
CHECK TIME BUTTON	Phone number: 5551234 Password 397554 Choose an account 41144 Bob Smith p36 Console Power AC: OK Batt: Low Communication Status Connoul Batt: Low Communication Status Connoul Emergency System Personal Emergency System Console Time, Event Log Chocek time Upp Console Time, Event Log Chocek time Local time: 13.27 - Fit, Daylight Savings Time: A Close	dde Inne Get evenis ii. Jan 28. 2005 Console DST auto adjust: 17 Jan 28. 2005	UPDATE TIME BUTTON

### **PURPOSE:**

For setting the Console's real time clock. The Console's clock controls the playing of the Reminder Messages. The RA-2400 will set the Console's clock to the Computer's clock time and date. A local time offset number can be entered for programming units that are in a different time zone from the Computer. Automatic daylight savings time adjustment for the Console is also selectable.

NOTE: If the Reminder Message feature is not going to be used, the Console's clock does not need to be set.

# USER RESPONSE:

# CONSOLE TIME, EVENT LOG

- NOTE: The Event Log feature is not supported in the PERS-3600.
- If the Console is located in another time zone, set the HOURS OFFSET FROM LOCAL number to how many hours difference (plus or minus) the Console's time is from the local time. If the Console is located in the same time zone as the Computer, set the value at 0.
- Check the DST AUTO ADJUST box for Console's in states where daylight savings time is observed.
- Click the UPDATE TIME button to send the time and date to the Console. The Computer's local time and date will be displayed at the bottom of the window.
- Click the CHECK TIME button to check the Console's time. The Console's current time and date will be displayed.

Sen	d / Receive		
	Phone Number: 5551234	Connect Disconnect	SEND BUTTON
	Password: 987654	Send data to console	
	Choose an account: 41144 Bob Smith.p20	Receive data from console Activity Timer	
	Console Power AC: OK Batt: OK	On      Refresh     Comm Setup	
	Communication status Data sent successfully		
	Console Time, Event Log Check Time Upd Console time: 13:27 - Fr Hours offset Iffrom localt 3 +		
	Local time: 10:27 - Fri, Daylight Savings Time: Au Close		

#### **PURPOSE:**

For transferring data from an Account Profile to a Console. Also used to monitor Console power and control Activity Timer status.

### **USER RESPONSE:**

### SENDING

 Click the SEND DATA TO CONSOLE button. The Communications Status area will indicate the progress and show if the data was sent to the Console successfully.

#### **SPECIAL NOTES:**

You can make changes to the Account Profile while the Console is connected. Be sure to send any changes to the Console before disconnecting. Minimize the Send/Receive window or slide it out of the way before editing the Account Profile. There is a time limit to the connection. The Console will automatically disconnect after three minutes of inactivity.

# 6.7 RECEIVING DATA

Send / Receive		
Phone Number: 5551234	Connect Disconnect	
Password: 987654	Send data to console	RECEIVE BUTTON
Choose an account: 41144 Bob Smith.p20	Activity Timer	
Console Power AC: OK Batt: OK	Refresh Comm Setup	
Communication status Received data successfully		
Console Time, Event Log Check Time Up Console time: 13:27 - F Hours offset 3	_	
Local time: 10:27 - Fri, Daylight Savings Time: A Close		

#### **PURPOSE:**

For transferring data from a Console to an Account Profile.

CAUTION: Receiving the data from the Console will overwrite the data in the Account Profile. If you have made changes to the Account Profile, save the profile, then SEND the profile to the Console <u>before</u> receiving the data into the profile. This leaves previously learned sensor information unchanged. If this is a new Account Profile, its OK to receive the Console data into the new profile.

#### **USER RESPONSE:**

#### RECEIVING

 Click the RECEIVE DATA FROM CONSOLE button. The Communications Status area will indicate the progress and show if the data was received from the Console successfully.

#### **SPECIAL NOTES:**

You can make changes to the Account Profile while the Console is connected. Be sure to send any changes to the Console before disconnecting. Minimize the Send/Receive window or slide it out of the way before editing the Account Profile. There is a time limit to the connection. The Console will automatically disconnect after three minutes of inactivity.

# 6.8 DISCONECTING FROM THE CONSOLE

s	end / Receive		
	Phone Number: 5551234	Connect Disconnect	DISCONNECT
	Password: 987654	Send data to console	5011011
	Choose an account: 41144 Bob Smith.p20	Activity Timer	
	Console Power AC: OK Batt: OK	Refresh Comm Setup	
	Communication status Received data successfully		
	Console Time, Event Log		
	Check Time Up Console time: 13:27 - F	date Time Get Events ii, Jan 28, 2005	
	Hours offset 3	Console DST auto adjust: 🔽	
	Local time: 10:27 - Fri, Daylight Savings Time: A Close		

# **PURPOSE:**

For terminating the connection bewteen the RA-2400 and the Console.

### **USER RESPONSE:**

# DISCONNECTING

 When finished communicating with the Console, click on the DISCONNECT button. The Communication Status area will show "Not Connected" when the Console has been disconnected.

# 6.9 CLOSING RA-2400

🐬 Linear - Ren			
File View Commu	unications Option	s Window	Help
New	Ctrl+N	<b>2</b> 3	
Open	Ctrl+O		
Close			
Save	Ctrl+S		_
Save As			Custom
Print	Ctrl+P		
Print Preview	Cuitte		Custo
Print Setup			
1 41144 Bob Smi	th.p36		
2 PERS-3600.p3(	6		Ad
Exit			Ad

#### **PURPOSE:**

To save the active Account Profile(s) and quit the RA-2400 program.

### **USER RESPONSE:**

- ✦ From the FILE menu, choose EXIT or close the RA-2400 window.
- ✤ To save while exiting, in the SAVE CHANGES? window click YES.

If the active Account Profile is the default template, select a location and new name for the file and click **SAVE**.

If the active Account Profile already has a custom file name, it will be saved with the same name.

NOTE: If more than one Account Profile template is open and has been changed, additional SAVE CHANGES? windows will appear.

#### **IMPORTANT:**

AFTER ANY PROGRAMMING CHANGES ARE MADE TO A CONSOLE, PERFORM THROUGH TESTING TO VERIFY THAT THE CONSOLE OPERATES AS INTENDED.