



# Radionics™ D2812

This system should be installed in accordance with Chapter 2 of the National Fire Alarm Code, ANSI/NFPA 72-1996, (NFPA, Batterymarch Park, Quincy MA 02269). Printed information describing proper installation, operation, testing, maintenance, repair service and response to an alarm is to be provided with this equipment. **Warning:** Owner's Instruction Notice: Not to be removed by anyone except occupant.

Radionics recommends testing the entire system at least once a week, and having a qualified technician check the system at a minimum of once every 3 years.

This equipment has been type tested and found to comply with the specifications in Part 15 of FCC rules for Class B Computing Devices. Operation is subject to the two following conditions (1) this device may not cause any interference, and (2) this device must accept any interference received including interference that may cause undesired operation.

Suitable for the following applications:

- 1) Household Burglar Alarm System Units, Grade A.
- 2) Household Fire Warning System Units.
- 3) Police Station connect, Grade A Mercantile Premise alarm system, Grade A Mercantile Safe and Vault alarm system and Grade AA Mercantile Safe and Vault alarm system when installed in conjunction with Model D8122 derived channel subscriber terminal unit. For all Police Station applications and grades, Model D8108A Attack Resistant Enclosure with a UL Listed local sounding device is required.
- 4) Local, Grade A Mercantile Premise alarm system and Grade A Mercantile Safe and Vault alarm system. For all local applications and grades, Model D8108A Attack Resistant Enclosure and a UL Listed local sounding device is required.
- 5) Central Station Mercantile, Grade C application, Central Station Mercantile, Grade B when installed with a UL Listed local sounding device. Central Station Mercantile, Grade AA when installed with Model D8122 derived channel subscriber terminal unit.
- 6) Proprietary Burglar Alarm units, Grade B, when installed with a UL Listed local sounding device. Proprietary Burglar Alarm unit, Grade BB when installed with the Model D8122 derived channel subscriber terminal unit. D2812 must be installed in accordance with Installation Instructions P/N 33120.

Complies with Part 68, FCC Rules.

FCC Registration Number: ESVUSA-30727-AL-E  
Ringer Equivalence: 0.3B

