D9412G/D7412G

Security Systems

EN

Program Record Sheet

Control Panels

BOSCH

This Program Record Sheet contains the entries found in the new record of the **9000MAIN**, **RADXUSR1**, **RADXUSR2**, **RADXPNTS**, **RADXSKED**, **RADXAUX1**, and **RADXAXS** product handlers. It includes all custom options. This Program Record Sheet may also be used for D9412, D9112, D7412, and D7212 Control Panels.

Note: ***IMPORTANT!*** *Please note that the D7212G Control Panel has different capabilities and different programming requirements than all other control panels in the 9000 Series. Using this manual to program a D7212***G** *Control Panel may cause unexpected results.* ***Please refer to the D7212G Program Record Sheet (P/N: 4998138542) when programming your D7212G Control Panel.***

SUMMARY ACCOUNT INFORMATION

Subscriber Name	_____			Date	_____
Address	_____				
City / State / Zip	_____				
Premises Phone	_____				
Installer Name	_____			Record Name	_____
Control Panel Location	_____		_____	Phone #	_____
Aux Power Current Load	_____ mA	AC Voltage	_____ VAC	Battery Voltage	_____ VDC
Earth Ground Location	_____			RJ31X/RJ38X	_____
Transformer Location	_____				
Bell/Siren Locations	_____				

Area	Account #	Area Description
1	_____	_____
2	_____	_____
3	_____	_____
4	_____	_____
5	_____	_____
6	_____	_____
7	_____	_____
8	_____	_____

Default values are shown in ( ) or in **bold** **9000MAIN Handler**

Panel Wide Parameters

Phone

Phone 1 ___
Phone 2 ___
Phone 3 ___
Phone 4 ___

Phone Parameters

Modem Format	**Yes** / No	Buzz On Fail	Yes / **No**
Point/User Flag	Yes / **No**	Two Phone Lines	Yes / **No**
DTMF Dialing	**Yes** / No	BFSK Duress Code (0)	_____
Phone Supv Time (Blank)	_____	Expand Test Rpt	Yes / **No**
Alarm On Fail	Yes / **No**	Ground Start	Short / **Long**

Routing

Routing Options: Primary (Blank, 1 to 4), Backup (Blank, 1 to 4)

	Route 1	Route 2	Route 3	Route 4
Primary Device (Blank)	_____	_____	_____	_____
Backup Device (Blank)	_____	_____	_____	_____

View Events Yes / **No**

Fire Reports	Route 1	Route 2	Route 3	Route 4
Fire Alarm	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Fire Restoral* (After Alarm)	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Fire Missing	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Fire Trouble	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Fire Supervision	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Fire Restoral*	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Fire Cancel	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Fire Supervision Missing	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Fire Supervision Restoral	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**

Burglar Reports				
Alarm Report	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Burg Restore	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Duress	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Missing Alarm	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
User Code Tamper	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Trouble Report**	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Missing Trouble	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Non-Fire Supervision	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Point Bus Fail	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Point Bus Restoral	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Non-Fire Cancel	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Alarm Restore	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Supervision Missing	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Unverified Event†	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**

Routing Table continued on next page

* *Restoral after Trb/Msg/Sup/Bypass. See Fire Supervision Res Event Type prompt in RADXAUX1 for further programming information.*

** *Trouble Reports include Point Low Battery conditions from Premises RF Points.*

† *This event is available only with the D9412G and does not get reported using BFSK format. Additionally, this event will not produce a corresponding Restoral event.*

[ ] *Heavy outline indicates parameters are available only when* View Events *is programmed YES.*

9000MAIN Handler Default values are shown in ( ) or in **bold**

Panel Wide Parameters (continued)

Routing (continued)

User Reports	Route 1	Route 2	Route 3	Route 4
Point Bypass/Command Bypass	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Forced Point	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Point Opening	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Point Closing	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Was Force Armed	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Fail To Open	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Fail To Close	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Extend Close Time	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Opening Report	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Forced Close	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Closing Report	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Forced Close Perim Instant	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Forced Close Perim Delay	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Perimeter Instant Armed	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Perimeter Delay Armed	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Send User Text	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No

Test Reports				
S: Alarm	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
S: Trouble	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
S: Supervision	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Status Report	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
S: Open	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
S: Close	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Test Report*	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
S: Perimeter Instant	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
S: Perimeter Delay	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
S: Fire Supervision	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
S: Fire Alarm	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
S: Fire Trouble	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
S: Missing Fire (Trouble)	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
S: Missing Burglary ((Trouble)	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
S: Missing Burglary (Alarm)	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
S: Fire Supervision Missing	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
S: Burglary Supervision Missing	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
S: Door Left Open	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No

Routing Table continued on next page

* *Please see the* D9412G/D7412G Program Entry Guide *(P/N: 47775) for additional information on how to generate Off-Normal Test Reports.*

Default values are shown in ( ) or in **bold** **9000MAIN Handler**

Panel Wide Parameters (continued)

Routing (continued)

Diagnostic Reports	**Route 1**	**Route 2**	**Route 3**	**Route 4**
SDI Device Failure	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
SDI Device Restoral	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Watchdog Reset	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Parameter Checksum Fail	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Reboot	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Phone Line Fail	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Phone Line Restoral	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
AC Failure	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
AC Restoral	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Battery Missing	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Battery Low	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Battery Restoral	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Route Comm Fail	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Route Comm Restore	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Checksum Fail	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Network Fail	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Network Restoral	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Network Condition	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**

Relay Reports				
Sensor Reset	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Relay Set	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Relay Reset	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No

Auto Function Reports				
Sked Executed	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Sked Changed	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Fail to Execute	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No

RAM Reports				
Event Log Threshold	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Event Log Overflow	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Parameters Changed	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
RAM Access OK	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
RAM Access Fail	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Remote Reset	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Program Access OK	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Program Access Fail	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No

Point Reports				
Service Start	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Service End	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Fire Walk Start	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Fire Walk End	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Walk Test Start	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Walk Test End	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Extra Point	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Send Point Text	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
RF Low Battery	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
RF Low Battery Restore	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**

Routing Table continued on next page

9000MAIN Handler Default values are shown in ( ) or in **bold**

Panel Wide Parameters (continued)

Routing (continued)

User Change Reports	Route 1	Route 2	Route 3	Route 4
Date Changed	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Time Changed	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Delete User	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
User Code Change	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Area Watch	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Card Assigned	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Change Level	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No

Access Reports				
Access Granted	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Access Denied	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Door Left Open	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Cycle Door	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Door Unlocked	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Door Secure	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Door Request	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Door Locked	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No

Enhanced Routing

RG1 Primary SDI	Yes / **No**
RG1 Backup SDI	Yes / **No**
RG1 Pager	Yes / **No**
RG2 Primary SDI	Yes / **No**
RG2 Backup SDI	Yes / **No**
RG2 Pager	Yes / **No**
RG3 Primary SDI	Yes / **No**
RG3 Backup SDI	Yes / **No**
RG3 Pager	Yes / **No**
RG4 Primary SDI	Yes / **No**
RG4 Backup SDI	Yes / **No**
RG4 Pager	Yes / **No**

Power Supervision

AC Fail Time* (15)	_____
AC Fail/Res Rpt	Yes / **No**
AC Tag Along	**Yes** / No
AC/Battery Buzz	Yes / **No**
Bat Fail/Res Rpt	**Yes** / No

**AC Fail Time interval is in seconds for Revisions 5.04 and 5.20. AC Fail Time interval is in minutes for Revisions 5.22, 5.24, 5.26, 6.00, and 6.10. Please review the* D9412G/D7412G Program Entry Guide *(P/N: 47775) for Revision 6.20 and higher.*

Default values are shown in ( ) or in **bold** **9000MAIN Handler**

Panel Wide Parameters (continued)

Printer Parameters

	Address #17	Address #18†	Address #19†
Area Assignment (1)	_____	_____	_____
Supervision Scope*	Yes / **No**	Yes / **No**	Yes / **No**
Area 1 in Scope	Yes / **No**	Yes / **No**	Yes / **No**
Area 2 in Scope	Yes / **No**	Yes / **No**	Yes / **No**
Area 3 in Scope	Yes / **No**	Yes / **No**	Yes / **No**
Area 4 in Scope	Yes / **No**	Yes / **No**	Yes / **No**
Area 5 in Scope	Yes / **No**	Yes / **No**	Yes / **No**
Area 6 in Scope	Yes / **No**	Yes / **No**	Yes / **No**
Area 7 in Scope	Yes / **No**	Yes / **No**	Yes / **No**
Area 8 in Scope	Yes / **No**	Yes / **No**	Yes / **No**
Fire Events	**Yes** / No	Yes / **No**	Yes / **No**
Burglar Events	**Yes** / No	Yes / **No**	Yes / **No**
Access Events	**Yes** / No	Yes / **No**	Yes / **No**
User Events	**Yes** / No	Yes / **No**	Yes / **No**
Test Events	**Yes** / No	Yes / **No**	Yes / **No**
Diagnostic Events	**Yes** / No	Yes / **No**	Yes / **No**
Auto Function Events	**Yes** / No	Yes / **No**	Yes / **No**
RAM Events	**Yes** / No	Yes / **No**	Yes / **No**
Relay Events	**Yes** / No	Yes / **No**	Yes / **No**
Point Events	**Yes** / No	Yes / **No**	Yes / **No**
User Change Events	**Yes** / No	Yes / **No**	Yes / **No**

**Scope Options: Account, Area, Panel-Wide, Custom, No Printer (Default = No Printer)*

†Addresses 18 and 19 available with the D9112, D9412, and D9412G only.

Double line outline indicates parameters are individually programmable only when Scope *is programmed CUSTOM.*

RAM Parameters

RAM Passcode (999999) _____

Log % Full (Blank) _____

RAM Call Back Yes / **No**

RAM Line Monitor **Yes** / No

Answer Armed (7) _____

Answer Disarmed (7) _____

RAM Phone: __

Miscellaneous

Duress Type **1** or 2

Cancel Reports Yes / **No**

9000MAIN Handler Default values are shown in ( ) or in **bold**

Area Wide Parameters

Area Parameters

	Area 1	Area 2	Area 3	Area 4	Area 5	Area 6	Area 7	Area 8
Area On	**Yes** / No	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Account Number (0000)	_____	_____	_____	_____	_____	_____	_____	_____
FA Bypass Max (1)	_____	_____	_____	_____	_____	_____	_____	_____
Delay Res	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Exit Tone	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Exit Dly Time (60)	_____	_____	_____	_____	_____	_____	_____	_____
Auto Watch	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Verify Time (60)	_____	_____	_____	_____	_____	_____	_____	_____
Duress Enable	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Area Type* (Regular)	_____	_____	_____	_____	_____	_____	_____	_____

* *Area Type options: Regular / Master / Assoc. / Shared.*

Bell Parameters

	Area 1	Area 2	Area 3	Area 4	Area 5	Area 6	Area 7	Area 8
Fire Time (6)	_____	_____	_____	_____	_____	_____	_____	_____
Fire Pattern** (Pulse)	_____	_____	_____	_____	_____	_____	_____	_____
Burg Time (6)	_____	_____	_____	_____	_____	_____	_____	_____
Burg Pattern** (Steady)	_____	_____	_____	_____	_____	_____	_____	_____
Single Ring	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Bell Test	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**

** *Pattern options: Steady / Pulse March Time / CA Standard / Temporal Code 3.*

Open/Close Options

	Area 1	Area 2	Area 3	Area 4	Area 5	Area 6	Area 7	Area 8
Acct O/C	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Area O/C	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Disable O/C in Window	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Auto Close	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Fail To Open	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Fail To Close	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Restricted O/C	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Perimeter O/C	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**

Default values are shown in ( ) or in **bold** **9000MAIN Handler**

Command Center

Command Center Assignments

	Address 1	Address 2	Address 3	Address 4	Address 5	Address 6	Address 7	Address 8
Supervision	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Area Assigned (1)	_____	_____	_____	_____	_____	_____	_____	_____
Scope*	_____	_____	_____	_____	_____	_____	_____	_____
Area 1 in Scope	**Yes** / No	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Area 2 in Scope	**Yes** / No	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Area 3 in Scope	**Yes** / No	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Area 4 in Scope	**Yes** / No	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Area 5 in Scope	**Yes** / No	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Area 6 in Scope	**Yes** / No	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Area 7 in Scope	**Yes** / No	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Area 8 in Scope	**Yes** / No	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Enter Key Relay (Blank)	__ __ __	__ __ __	__ __ __	__ __ __	__ __ __	__ __ __	__ __ __	__ __ __
Enter Key Cycle Door	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Assign Door (Blank)	__	__	__	__	__	__	__	__
Trouble Tone	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Entry Tone	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Exit Tone	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Arm Area Warning Tone	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Close Door Warning Tone	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Enhanced Cmd Ctr**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**

* *Scope Options: Account, Area, Panel-Wide, Custom, No Keypad. Default Address 1 = Panel-Wide; Address 2 to 8 = No Keypad.*

** *Turn Enhanced Command Center prompt to Yes if a D1260 Alpha V Command Center is installed at this address.*

Double line outline indicates parameters are individually programmable only when Scope *is programmed CUSTOM.*

Command Center Installation Locations

1	9	17	25
2	10	18	26
3	11	19	27
4	12	20	28
5	13	21	29
6	14	22	30
7	15	23	31
8	16	24	32

9000MAIN Handler Default values are shown in ( ) or in **bold**

Command Center (continued)

Area Text

Area 1		
Area # Is On	**(A1 AREA 1 IS ON)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Not Ready	**(A1 NOT READY)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Is Off	**(A1 AREA 1 IS OFF)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Acct Is On	**(A1 ACCOUNT IS ON)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area 2		
Area # Is On	**(A2 AREA 2 IS ON)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Not Ready	**(A2 NOT READY)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Is Off	**(A2 AREA 2 IS OFF)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Acct Is On	**(A2 ACCOUNT IS ON)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area 3		
Area # Is On	**(A3 AREA 3 IS ON)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Not Ready	**(A3 NOT READY)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Is Off	**(A3 AREA 3 IS OFF)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Acct Is On	**(A3 ACCOUNT IS ON)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area 4		
Area # Is On	**(A4 AREA 4 IS ON)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Not Ready	**(A4 NOT READY)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Is Off	**(A4 AREA 4 IS OFF)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Acct Is On	**(A4 ACCOUNT IS ON)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area 5		
Area # Is On	**(A5 AREA 5 IS ON)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Not Ready	**(A5 NOT READY)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Is Off	**(A5 AREA 5 IS OFF)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Acct Is On	**(A5 ACCOUNT IS ON)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area 6		
Area # Is On	**(A6 AREA 6 IS ON)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Not Ready	**(A6 NOT READY)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Is Off	**(A6 AREA 6 IS OFF)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Acct Is On	**(A6 ACCOUNT IS ON)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area 7		
Area # Is On	**(A7 AREA 7 IS ON)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Not Ready	**(A7 NOT READY)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Is Off	**(A7 AREA 7 IS OFF)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Acct Is On	**(A7 ACCOUNT IS ON)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area 8		
Area # Is On	**(A8 AREA 8 IS ON)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Not Ready	**(A8 NOT READY)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Is Off	**(A8 AREA 8 IS OFF)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___
Area # Acct Is On	**(A8 ACCOUNT IS ON)**	___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___ ___

Default values are shown in ( ) or in **bold** **9000MAIN Handler**

Command Center (continued)

Custom Functions

CF 128	Text	_ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
	Key Strokes	_ _
CF 129	Text	_ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
	Key Strokes	_ _
CF 130	Text	_ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
	Key Strokes	_ _
CF 131	Text	_ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
	Key Strokes	_ _
CF 132†	Text	_ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
	Key Strokes	_ _
CF 133†	Text	_ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
	Key Strokes	_ _
CF 134†	Text	_ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
	Key Strokes	_ _
CF 135†	Text	_ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
	Key Strokes	_ _
CF 136†	Text	_ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
	Key Strokes	_ _
CF 137†	Text	_ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
	Key Strokes	_ _
CF 138†	Text	_ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
	Key Strokes	_ _
CF 139†	Text	_ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
	Key Strokes	_ _
CF 140†	Text	_ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
	Key Strokes	_ _
CF 141†	Text	_ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
	Key Strokes	_ _
CF 142†	Text	_ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
	Key Strokes	_ _
CF 143†	Text	_ _ _ _ _ _ _ _ _ _ _ _ _ _ _ _
	Key Strokes	_ _

† *Custom Functions #132 and higher available with the D9112, D9412, and D9412G only.*

Custom Function Key Codes		
0-9	=	0-9
A	=	COMMAND
B	=	PREV
C	=	ESC
D	=	NEXT
E	=	ENT

**** Follow this chart when using single digit commands ****			
Command……		**Command……**	
1 Master Arm Area……	A**1**9	**7** Special Alert……....	A**7**9
2 Perimeter Instant Arm ……..	A**2**9	**8** Perimeter Partial Arm …..	A**8**9
3 Perimeter Delay Arm…….....	A**3**9	**9** Special Alert…….....	A**9**9
6 Watch Mode …….....	A**6**9	**0** Bypass a Point …….	A**0**9

9000MAIN Handler Default values are shown in ( ) or in **bold**

User Interface

Command Center Functions				Authority Levels†														
#	Functions	Command	E/P*	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
1	Disarm ?		P	E	E	E	E	E										
2	Master Arm Delay ?	CMD 1	P	E	E	E	E	E										
3	Master Arm Instant?	CMD 11		E	E													
4	Perimeter Instant ?	CMD 2	P	E	E	E	E											
5	Perimeter Delay ?	CMD 3	P	E	E	E	E											
6	Watch Mode ?	CMD 6	E	E	E	E												E
7	Perimeter Part ?	CMD 8	P	E	E	E	E											
8	View Area Status ?		P	E	E													E
9	View Memory ?	CMD 40	E	E	E	E												E
10	View Pt Status ?		E	E	E	E												E
11	Walk Test ?	CMD 44	E	E	E													E
12	Fire Test ?	CMD 58	P	E	E													E
13	Send Report ?	CMD 41/42	P															E
14	Door Control ?	CMD 46	P	E	E													E
	Cycle Door ?		E	E	E													E
	Unlock Door ?		E	E	E													E
	Secure Door ?		E	E														E
37	Access Control Level?		P	E														E
15	Change Display ?	CMD 49	E	E														E
16	Change Time/Date ?	CMD 45	E	E														E
17	Change Passcode ?	CMD 55	P	E														E
18	Add User ?	CMD 56	P	E														E
19	Del User ?	CMD 53	P	E														E
20	Extend Close ?	CMD 51	P															E
21	View Log ?		E	E														E
22	Print Log ?		P	E														E
23	User Command 7 ?	CMD 7	P															E
24	User Command 9 ?	CMD 9	P															E
25	Bypass a Point ?	CMD 0	P	E	E	E	E											E
26	Unbypass a Point ?	CMD 00	P	E	E	E	E											E
27	Reset Sensors ?	CMD 47	E	E	E	E	E											E
28	Change Relays ?	CMD 54	P	E	E													E
29	Remote Program ?	CMD 43	P	E	E	E	E											E
30	Move To Area ?	CMD 50	P	E	E													E
32	Display Rev ?	CMD 59	E	E														E
33	Service Walk ?		P															E
34	Default Text ?	CMD 57	P															E
35	Change Skeds ?	CMD 52	P	E														E

* *Command Center Function options: P = Passcode required, E = Enabled (no Passcode required), Blank = Disabled.*

† *Authority Level options: E = Enabled, Blank = Disabled.*

Solid box indicates parameter is not user programmable.

Default values are shown in ( ) or in **bold** **9000MAIN Handler**

User Interface (continued)

Command Center Functions			Authority Levels†													
#	Custom Functions	E/P*	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
128	Custom Function 128	P	E														
129	Custom Function 129	P	E														
130	Custom Function 130	P	E														
131	Custom Function 131	P	E														
132	Custom Function 132**	P	E														
133	Custom Function 133**	P	E														
134	Custom Function 134**	P	E														
135	Custom Function 135**	P	E														
136	Custom Function 136**	P	E														
137	Custom Function 137**	P	E														
138	Custom Function 138**	P	E														
139	Custom Function 139**	P	E														
140	Custom Function 140**	P	E														
141	Custom Function 141**	P	E														
142	Custom Function 142**	P	E														
143	Custom Function 143**	P	E														

* *Command Center Function options: P = Passcode required, E = Enabled (no Passcode required), Blank = Disabled.*
† *Authority Level options: E = Enabled, Blank = Disabled.*
** *Custom Functions #132 and higher available with the D9112, D9412, and D9412G only.*

		Authority Levels†														
#	Report Levels	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
	Force Arm ?	E	E	E	E	E	E									
	Area O/C ?															
	Restricted O/C ?															
	Perimeter O/C ?															
	Send Duress ?	E	E	E	E	E	E	E	E	E	E	E	E	E	E	
	Passcode Arm ?	E	E	E	E	E	E									
	Passcode Disarm ?	E	E	E	E	E										

† *Authority Level options: E = Enabled, Blank = Disabled.*

		Authority Levels														
#	Access Levels	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
	Security Level ?*	M	M	P	P	P	D									
	Disarm Level ?**	I	D	D	D	D										

* *Security Level options for Authority Levels: M = Any Armed State, P = Perimeter Armed, D = Disarmed, Blank = No Access*
** *Disarm Level options for Authority Levels: I = Disarm to Perimeter Instant, D = Disarm All, Blank = No Disarm Rights*

9000MAIN Handler Default values are shown in ( ) or in **bold**

Function List

Menu Item	Function	CC Address 1	CC Address 2	CC Address 3	CC Address 4	CC Address 5	CC Address 6	CC Address 7	CC Address 8
1	(6) ___	**Yes**/No	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
2	(27) ___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
3	(29) ___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
4	(11) ___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
5	(15) ___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
6	(16) ___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
7	(17) ___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
8	(18) ___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
9	(19) ___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
10	(25) ___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
11	(26) ___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
12	(9) ___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
13	(10) ___	**Yes**/No	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
14	(8) ___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
15	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
16	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
17	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
18	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
19	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
20	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
21	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
22	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
23	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
24	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
25	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
26	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
27	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
28	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
29	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
30	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
31	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
32	___	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**

Default values are shown in ( ) or in **bold** **9000MAIN Handler**

Relay Parameters

Area Relays

	AREA							
	1	2	3	4	5	6	7	8
Alarm Bell*	A	A	A	A	A	A	A	A
Fire Bell*	A	A	A	A	A	A	A	A
Reset Sensors*	C	C	C	C	C	C	C	C
Fail To Close								
Force Armed								
Watch Mode*								
Area Armed*								
Area Fault								
Duress Relay*								
Perim Fault								
Silent Alarm								

**The same relay can be shared between areas and functions. A different relay must be used for each area and/or function unless indicated by the asterisk (*).*

Panel Wide Relays

AC Failure	_____
Battery Trouble	_____
Phone Fail	_____
Comm Fail	_____
Log % Full	_____
Summary Fire	_____
Summary Alarm	_____
Summary Fire Trouble	_____
Summary Supv Fire	_____
Summary Trouble	_____
Summary Supv Burg	_____

Relay #, Description	Relay #, Description	Relay #, Description	Relay #, Description
A	31	64	97†
B	32	65†	98†
C	33	66†	99†
1	34	67†	100†
2	35	68†	101†
3	36	69†	102†
4	37	70†	103†
5	38	71†	104†
6	39	72†	105†
7	40	73†	106†
8	41	74†	107†
9	42	75†	108†
10	43	76†	109†
11	44	77†	110†
12	45	78†	111†
13	46	79†	112†
14	47	80†	113†
15	48	81†	114†
16	49	82†	115†
17	50	83†	116†
18	51	84†	117†
19	52	85†	118†
20	53	86†	119†
21	54	87†	120†
22	55	88†	121†
23	56	89†	122†
24	57	90†	123†
25	58	91†	124†
26	59	92†	125†
27	60	93†	126†
28	61	94†	127†
29	62	95†	128†
30	63	96†	

Note: Please refer to the D9412G/D7412G Program Entry Guide *(P/N: 47775) for additional Silent Alarm Relay functionality.*

† *Relays 65 and higher available with the D9112, D9412, and D9412G only.*

RADXUSR1 Handler Default values are shown in ( ) or in **bold**

User (Passcode) Worksheet (Users 000 to 029)

User ###	Passcode	User Group	Area Authority 1	2	3	4	5	6	7	8	User Name
000	123 __ __ __ __ __ __	____	**15**	**15**	**15**	**15**	**15**	**15**	**15**	**15**	SERVICE PASSCODE
001	123456 __ __ __ __ __	____	1__	__	__	__	__	__	__	__	USER 1
002	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 2
003	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 3
004	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 4
005	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 5
006	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 6
007	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 7
008	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 8
009	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 9
010	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 10
011	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 11
012	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 12
013	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 13
014	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 14
015	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 15
016	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 16
017	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 17
018	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 18
019	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 19
020	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 20
021	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 21
022	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 22
023	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 23
024	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 24
025	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 25
026	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 26
027	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 27
028	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 28
029	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER 29

Default values are shown in ( ) or in **bold** **RADXUSR1 Handler**

User (Token) Worksheet (Users 000 to 029)

User ###	Master ID ### - 0		Sub-User ID ### - 1		Sub-User ID ### - 2		Sub-User ID ### - 3	
	Site	Card Data	Site	Card Data	Site	Card Data	Site	Card Data
000	Not available							
001								
002								
003								
004								
005								
006								
007								
008								
009								
010								
011								
012								
013								
014								
015								
016								
017								
018								
019								
020								
021								
022								
023								
024								
025								
026								
027								
028								
029								

RADXUSR1/RADXUSR2 Handlers Default values are shown in ( ) or in **bold**

Additional User (Passcode) Worksheet (Users __ __ __ to __ __ __)

Use this worksheet to record up to 30 additional users. Photocopy this sheet as needed.
For Users 000 to124, use RADXUSR1 Handler. For Users 125 to 249, use RADXUSR2 Handler.

User ###	Passcode	User Group	Area Authority 1	2	3	4	5	6	7	8	User Name	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	
	__ __ __ __ __ __	____	__	__	__	__	__	__	__	__	USER	

Default values are shown in ( ) or in **bold** **RADXUSR1/RADXUSR2 Handlers**

Additional User (Token) Worksheet (Users __ __ __ to __ __ __)

Use this worksheet to record up to 30 additional users. Photocopy this sheet as needed.
For Users 000 to124, use RADXUSR1 Handler. For Users 125 to 249, use RADXUSR2 Handler.

User ###	Master ID ### - 0		Sub-User ID ### - 1		Sub-User ID ### - 2		Sub-User ID ### - 3	
	Site	Card Data	Site	Card Data	Site	Card Data	Site	Card Data

RADXPNTS Handler Default values are shown in ( ) or in **bold**

Point Index

Point Index Description Defaults:

1 24-Hour Instant Audible Alarm on Open or Short
2 Invisible/Silent Hold Up on Short
3 Fire Pull Station Alarm on Short
4 Smoke Detector w/Reset Alarm on Short
5 Smoke Detector with Verification Reset and Alarm on Short
6 Bell Supervision Trouble on Open or Short
7 Perimeter Instant Alarm on Open or Short, Watch Point When Disarmed
8 Perimeter Delay on Short, Instant Arm on Short. Watch Point when Disarmed

	Point Index Description							
Prompt **Point Index #**	**1**	**2**	**3**	**4**	**5**	**6**	**7**	**8**
Type	(0) ____	(0) ____	(0) ____	(0) ____	(0) ____	(0) ____	(1) ____	(1) ____
Point Response	(0) ____	(1) ____	(1) ____	(1) ____	(1) ____	(3) ____	(1) ____	(7) ____
Entry Delay	(5) ____	(5) ____	(5) ____	(5) ____	(5) ____	(5) ____	(5) ____	(30) ___
Entry Tone Off	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Silent Bell	Y/**N**	**Y**/N	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Ring Until Restored	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Audible After Two Fails	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Invisible Point	Y/**N**	**Y**/N	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Buzz on Fault	_____	_____	_____	_____	_____	(1) ____	_____	_____
Watch Point	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	**Y**/N	**Y**/N
Relay Response Type	_____	_____	_____	_____	_____	_____	_____	_____
Display as Device	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Local While Disarmed	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Local While Armed	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Disable Restorals	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
FA Returnable	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Bypass Returnable	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Bypassable	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Swinger Bypass	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Report Bypass at Occurrence	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Defer Bypass Report	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Cross Point	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Fire Point	Y/**N**	Y/**N**	**Y**/N	**Y**/N	**Y**/N	Y/**N**	Y/**N**	Y/**N**
Alarm Verify	Y/**N**	Y/**N**	Y/**N**	Y/**N**	**Y**/N	Y/**N**	Y/**N**	Y/**N**
Resettable	Y/**N**	Y/**N**	Y/**N**	**Y**/N	**Y**/N	Y/**N**	Y/**N**	Y/**N**

Point Type Selections			
0	24-Hour	6	O/C Point
1	Perimeter	7	D279 (O/C Non-Priority)
2	Interior	8	D279 (O/C Priority)
3	Interior Follower	9	Easikey
4	Keyswitch Maintained		
5	Keyswitch Momentary		

Point Response Selections*		**0**	**1**	**2**	**3**	**4**	**5**	**6**	**7**	**8**	**9**	**A**	**B**	**C**	**D**	**E**	**F**
Armed	Open	I	I	I	I	D	D	I	I	D	I	I	I	I	I	T	
	Short	I	I	I	I	I	I	D	D	D	I	I	I	I	I	I	
Disarmed	Open		T		T				T		I	I	T	I		T	
	Short			T	T		T				I	T	I		I		
24-Hour	Open	I	T	I	T			I	T	S	T	S		S	Not Applicable		
	Short	I	I	T	T	I	T			T	S		S	S			

**Selections: D = Delayed Response, I = Instant Alarm, S = Supervisory, T = Trouble, Blank = No Response*

Default values are shown in ( ) or in **bold** **RADXPNTS Handler**

Point Index (continued)

	Point Index Description							
Point Index Description Defaults: 9 Perimeter Instant Alarm on Open or Short, Local while Disarmed 10 Interior Instant Alarm on Open or Short 11 Interior Delay on Short, Alarm on Open 12 Interior Instant Alarm on Open or Short, Local While Disarmed 13 Interior Follower Delay on Short, Alarm on Open 14 Maintained Keyswitch 15 Momentary Keyswitch 16 Open/Close on Fault								
Prompt **Point Index #**	**9**	**10**	**11**	**12**	**13**	**14**	**15**	**16**
Type	(1) ____	(2) ____	(2) ____	(2) ____	(3) ____	(4) ____	(5) ____	(6) ____
Point Response	(B) ____	(1) ____	(7) ____	(B) ____	(7) ____	(1) ____	(1) ____	(1) ____
Entry Delay	(5) ____	(5) ____	(30) ___	(5) ____	(30) ___	(5) ____	(5) ____	(5) ____
Entry Tone Off	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Silent Bell	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Ring Until Restored	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Audible After Two Fails	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Invisible Point	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Buzz on Fault	(1)____	_____	_____	_____	_____	_____	_____	_____
Watch Point	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Relay Response Type	_____	_____	_____	_____	_____	_____	_____	_____
Display as Device	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Local While Disarmed	**Y**/N	Y/**N**	Y/**N**	**Y**/N	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Local While Armed	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Disable Restorals	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
FA Returnable	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Bypass Returnable	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Bypassable	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Swinger Bypass	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Report Bypass at Occurrence	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Defer Bypass Report	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Cross Point	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Fire Point	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Alarm Verify	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Resettable	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**

Point Type Selections			
0	24-Hour	6	O/C Point
1	Perimeter	7	D279 (O/C Non-Priority)
2	Interior	8	D279 (O/C Priority)
3	Interior Follower	9	Easikey
4	Keyswitch Maintained		
5	Keyswitch Momentary		

Point Response Selections*		**0**	**1**	**2**	**3**	**4**	**5**	**6**	**7**	**8**	**9**	**A**	**B**	**C**	**D**	**E**	**F**
Armed	Open	I	I	I	I	D	D	I	I	D	I	I	I	I	I	T	
	Short	I	I	I	I	I	I	D	D	D	I	I	I	I	I	I	
Disarmed	Open		T		T				T		I	I	T	I		T	
	Short			T	T		T				I	T	I		I		
24-Hour	Open	I	T	I	T			I	T	S	T	S		S	Not Applicable		
	Short	I	I	T	T	I	T			T	S		S	S			

**Selections: D = Delayed Response, I = Instant Alarm, S = Supervisory, T = Trouble, Blank = No Response*

RADXPNTS Handler Default values are shown in ( ) or in **bold**

Point Index (continued)

Point Index Description Defaults:	**Point Index Description**							
17 D279 (Non-Priority) 18 D279 (Priority) 19 Easikey Input 20 POPIT Motion Sensor Interior 21 POPIT Motion Sensor Perimeter 22 Fire Supervisory on Open, Trouble on Short 23 Non-Fire Supervisory on Open, Trouble on Short 24 Local, No Visual or Audible Display on Any Fault Armed or Disarmed with Relay Output								
Prompt **Point Index #**	**17**	**18**	**19**	**20**	**21**	**22**	**23**	**24**
Type	(7) ____	(8) ____	(9) ____	(2) ____	(1) ____	(0) ____	(0) ____	(1) ____
Point Response	(1) ____	(2) ____	(1) ____	(E) ____	(E) ____	(8) ____	(8) ____	(F) ____
Entry Delay	(5) ____	(5) ____	(5) ____	(5) ____	(5) ____	(5) ____	(5) ____	(5) ____
Entry Tone Off	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Silent Bell	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Ring Until Restored	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Audible After Two Fails	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Invisible Point	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Buzz on Fault	_____	_____	_____	_____	_____	_____	_____	_____
Watch Point	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Relay Response Type	_____	_____	_____	_____	_____	_____	_____	(1) ____
Display as Device	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Local While Disarmed	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Local While Armed	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Disable Restorals	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
FA Returnable	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Bypass Returnable	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Bypassable	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Swinger Bypass	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Report Bypass at Occurrence	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Defer Bypass Report	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Cross Point	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Fire Point	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	**Y**/N	Y/**N**	Y/**N**
Alarm Verify	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Resettable	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**

Point Type Selections			
0	24-Hour	6	O/C Point
1	Perimeter	7	D279 (O/C Non-Priority)
2	Interior	8	D279 (O/C Priority)
3	Interior Follower	9	Easikey
4	Keyswitch Maintained		
5	Keyswitch Momentary		

Point Response Selections*		**0**	**1**	**2**	**3**	**4**	**5**	**6**	**7**	**8**	**9**	**A**	**B**	**C**	**D**	**E**	**F**
Armed	Open	I	I	I	I	D	D	I	I	D	I	I	I	I	I	T	
	Short	I	I	I	I	I	I	D	D	D	I	I	I	I	I	I	
Disarmed	Open		T		T				T		I	I	T	I		T	
	Short			T	T		T				I	T	I		I		
24-Hour	Open	I	T	I	T			I	T	S	T	S		S	Not Applicable		
	Short	I	I	T	T	I	T			T	S		S	S			

**Selections: D = Delayed Response, I = Instant Alarm, S = Supervisory, T = Trouble, Blank = No Response*

Default values are shown in ( ) or in **bold** **RADXPNTS Handler**

Point Index (continued)

	Point Index Description						
Point Index Description Defaults: 25 Perimeter Delay on Open, Alarm on Short 26 24-Hour Instant Audible Alarm on Open or Short 27 24-Hour Instant Audible Alarm on Open or Short 28 24-Hour Instant Audible Alarm on Open or Short 29 24-Hour Instant Audible Alarm on Open or Short 30 24-Hour Instant Audible Alarm on Open or Short 31 24-Hour Instant Audible Alarm on Open or Short							
Prompt **Point Index #**	**25**	**26**	**27**	**28**	**29**	**30**	**31**
Type	(1) ____	(0) ____	(0) ____	(0) ____	(0) ____	(0) ____	(0) ____
Point Response	(4) ____	(0) ____	(0) ____	(0) ____	(0) ____	(0) ____	(0) ____
Entry Delay	(30) ___	(5) ____	(5) ____	(5) ____	(5) ____	(5) ____	(5) ____
Entry Tone Off	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Silent Bell	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Ring Until Restored	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Audible After Two Fails	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Invisible Point	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Buzz on Fault	_____	_____	_____	_____	_____	_____	_____
Watch Point	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Relay Response Type	_____	_____	_____	_____	_____	_____	_____
Display as Device	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Local While Disarmed	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Local While Armed	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Disable Restorals	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
FA Returnable	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Bypass Returnable	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Bypassable	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Swinger Bypass	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Report Bypass at Occurrence	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Defer Bypass Report	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Cross Point	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Fire Point	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Alarm Verify	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**
Resettable	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**	Y/**N**

Point Type Selections			
0	24-Hour	6	O/C Point
1	Perimeter	7	D279 (O/C Non-Priority)
2	Interior	8	D279 (O/C Priority)
3	Interior Follower	9	Easikey
4	Keyswitch Maintained		
5	Keyswitch Momentary		

Point Response Selections*		**0**	**1**	**2**	**3**	**4**	**5**	**6**	**7**	**8**	**9**	**A**	**B**	**C**	**D**	**E**	**F**
Armed	Open	I	I	I	I	D	D	I	I	D	I	I	I	I	I	T	
	Short	I	I	I	I	I	I	D	D	D	I	I	I	I	I	I	
Disarmed	Open		T		T				T		I	I	T	I		T	
	Short			T	T		T				I	T	I		I		
24-Hour	Open	I	T	I	T			I	T	S	T	S		S	Not Applicable		
	Short	I	I	T	T	I	T			T	S		S	S			

**Selections: D = Delayed Response, I = Instant Alarm, S = Supervisory, T = Trouble, Blank = No Response*

RADXPNTS Handler Default values are shown in ( ) or in **bold**

Point Assignments (001 through 040)

POPIT Switch Setting	Trans-lation	Point #	Point Index	Area Assign	Debounce	BFSK/ Relay	Custom Point Text
	100	001	(3) _ _	(1) ___	(2) _____	(1) ____	P1 FIRE _____
	200	002	(1) _ _	(1) ___	(2) _____	(2) ____	P2 PANIC _____
	300	003	(25) _ _	(1) ___	(2) _____	(3) ____	P3 DELAY _____
	400	004	(13) _ _	(1) ___	(2) _____	(4) ____	P4 FOLLOW _____
	500	005	(7) _ _	(1) ___	(2) _____	(5) ____	P5 INSTANT _____
	600	006	(7) _ _	(1) ___	(2) _____	(6) ____	P6 INSTANT _____
	700	007	(7) _ _	(1) ___	(2) _____	(7) ____	P7 INSTANT _____
	800	008	(7) _ _	(1) ___	(2) _____	(8) ____	P8 INSTANT _____
0 1 2 3 4 5 6	101	009	__ __	(1) ___	(2) _____	(1) ____	P9 _____
0 1 2 3 4 5 _	102	010	__ __	(1) ___	(2) _____	(1) ____	P10 _____
0 1 2 3 4 _ 6	103	011	__ __	(1) ___	(2) _____	(1) ____	P11 _____
0 1 2 3 4 _ _	104	012	__ __	(1) ___	(2) _____	(1) ____	P12 _____
0 1 2 3 _ 5 6	105	013	__ __	(1) ___	(2) _____	(1) ____	P13 _____
0 1 2 3 _ 5 _	106	014	__ __	(1) ___	(2) _____	(1) ____	P14 _____
0 1 2 3 _ _ 6	107	015	__ __	(1) ___	(2) _____	(1) ____	P15 _____
0 1 2 3 _ _ _	108	016	__ __	(1) ___	(2) _____	(1) ____	P16 _____
0 1 2 _ 4 5 6	109	017	__ __	(1) ___	(2) _____	(1) ____	P17 _____
0 1 2 _ 4 5 _	110	018	__ __	(1) ___	(2) _____	(1) ____	P18 _____
0 1 2 _ 4 _ 6	111	019	__ __	(1) ___	(2) _____	(1) ____	P19 _____
0 1 2 _ 4 _ _	112	020	__ __	(1) ___	(2) _____	(1) ____	P20 _____
0 1 2 _ _ 5 6	113	021	__ __	(1) ___	(2) _____	(1) ____	P21 _____
0 1 2 _ _ 5 _	114	022	__ __	(1) ___	(2) _____	(1) ____	P22 _____
0 1 2 _ _ _ 6	115	023	__ __	(1) ___	(2) _____	(1) ____	P23 _____
0 1 2 _ _ _ _	116	024	__ __	(1) ___	(2) _____	(1) ____	P24 _____
0 1 _ 3 4 5 6	201	025	__ __	(1) ___	(2) _____	(1) ____	P25 _____
0 1 _ 3 4 5 _	202	026	__ __	(1) ___	(2) _____	(1) ____	P26 _____
0 1 _ 3 4 _ 6	203	027	__ __	(1) ___	(2) _____	(1) ____	P27 _____
0 1 _ 3 4 _ _	204	028	__ __	(1) ___	(2) _____	(1) ____	P28 _____
0 1 _ 3 _ 5 6	205	029	__ __	(1) ___	(2) _____	(1) ____	P29 _____
0 1 _ 3 _ 5 _	206	030	__ __	(1) ___	(2) _____	(1) ____	P30 _____
0 1 _ 3 _ _ 6	207	031	__ __	(1) ___	(2) _____	(1) ____	P31 _____
0 1 _ 3 _ _ _	208	032	__ __	(1) ___	(2) _____	(1) ____	P32 _____
0 1 _ _ 4 5 6	209	033	__ __	(1) ___	(2) _____	(1) ____	P33 _____
0 1 _ _ 4 5 _	210	034	__ __	(1) ___	(2) _____	(1) ____	P34 _____
0 1 _ _ 4 _ 6	211	035	__ __	(1) ___	(2) _____	(1) ____	P35 _____
0 1 _ _ 4 _ _	212	036	__ __	(1) ___	(2) _____	(1) ____	P36 _____
0 1 _ _ _ 5 6	213	037	__ __	(1) ___	(2) _____	(1) ____	P37 _____
0 1 _ _ _ 5 _	214	038	__ __	(1) ___	(2) _____	(1) ____	P38 _____
0 1 _ _ _ _ 6	215	039	__ __	(1) ___	(2) _____	(1) ____	P39 _____
0 1 _ _ _ _ _	216	040	__ __	(1) ___	(2) _____	(1) ____	P40 _____

Default values are shown in ( ) or in **bold** **RADXPNTS Handler**

Point Assignments (041 through 080)

POPIT Switch Setting	Trans-lation	Point #	Point Index	Area Assign	Debounce	BFSK/ Relay	Custom Point Text
0 _ 2 3 4 5 6	301	041	__ __	(1) ___	(2) ____	(1) ____	P41 _____
0 _ 2 3 4 5 _	302	042	__ __	(1) ___	(2) ____	(1) ____	P42 _____
0 _ 2 3 4 _ 6	303	043	__ __	(1) ___	(2) ____	(1) ____	P43 _____
0 _ 2 3 4 _ _	304	044	__ __	(1) ___	(2) ____	(1) ____	P44 _____
0 _ 2 3 _ 5 6	305	045	__ __	(1) ___	(2) ____	(1) ____	P45 _____
0 _ 2 3 _ 5 _	306	046	__ __	(1) ___	(2) ____	(1) ____	P46 _____
0 _ 2 3 _ _ 6	307	047	__ __	(1) ___	(2) ____	(1) ____	P47 _____
0 _ 2 3 _ _ _	308	048	__ __	(1) ___	(2) ____	(1) ____	P48 _____
0 _ 2 _ 4 5 6	309	049	__ __	(1) ___	(2) ____	(1) ____	P49 _____
0 _ 2 _ 4 5 _	310	050	__ __	(1) ___	(2) ____	(1) ____	P50 _____
0 _ 2 _ 4 _ 6	311	051	__ __	(1) ___	(2) ____	(1) ____	P51 _____
0 _ 2 _ 4 _ _	312	052	__ __	(1) ___	(2) ____	(1) ____	P52 _____
0 _ 2 _ _ 5 6	313	053	__ __	(1) ___	(2) ____	(1) ____	P53 _____
0 _ 2 _ _ 5 _	314	054	__ __	(1) ___	(2) ____	(1) ____	P54 _____
0 _ 2 _ _ _ 6	315	055	__ __	(1) ___	(2) ____	(1) ____	P55 _____
0 _ 2 _ _ _ _	316	056	__ __	(1) ___	(2) ____	(1) ____	P56 _____
0 _ _ 3 4 5 6	401	057	__ __	(1) ___	(2) ____	(1) ____	P57 _____
0 _ _ 3 4 5 _	402	058	__ __	(1) ___	(2) ____	(1) ____	P58 _____
0 _ _ 3 4 _ 6	403	059	__ __	(1) ___	(2) ____	(1) ____	P59 _____
0 _ _ 3 4 _ _	404	060	__ __	(1) ___	(2) ____	(1) ____	P60 _____
0 _ _ 3 _ 5 6	405	061	__ __	(1) ___	(2) ____	(1) ____	P61 _____
0 _ _ 3 _ 5 _	406	062	__ __	(1) ___	(2) ____	(1) ____	P62 _____
0 _ _ 3 _ _ 6	407	063	__ __	(1) ___	(2) ____	(1) ____	P63 _____
0 _ _ 3 _ _ _	408	064	__ __	(1) ___	(2) ____	(1) ____	P64 _____
0 _ _ _ 4 5 6	409	065	__ __	(1) ___	(2) ____	(1) ____	P65 _____
0 _ _ _ 4 5 _	410	066	__ __	(1) ___	(2) ____	(1) ____	P66 _____
0 _ _ _ 4 _ 6	411	067	__ __	(1) ___	(2) ____	(1) ____	P67 _____
0 _ _ _ 4 _ _	412	068	__ __	(1) ___	(2) ____	(1) ____	P68 _____
0 _ _ _ _ 5 6	413	069	__ __	(1) ___	(2) ____	(1) ____	P69 _____
0 _ _ _ _ 5 _	414	070	__ __	(1) ___	(2) ____	(1) ____	P70 _____
0 _ _ _ _ _ 6	415	071	__ __	(1) ___	(2) ____	(1) ____	P71 _____
0 _ _ _ _ _ _	416	072	__ __	(1) ___	(2) ____	(1) ____	P72 _____
_ 1 2 3 4 5 6	501	073	__ __	(1) ___	(2) ____	(1) ____	P73 _____
_ 1 2 3 4 5 _	502	074	__ __	(1) ___	(2) ____	(1) ____	P74 _____
_ 1 2 3 4 _ 6	503	075	__ __	(1) ___	(2) ____	(1) ____	P75 _____
D7412G, D7412, and D7212 Maximum of 75 Points							
_ 1 2 3 4 _ _	504	076	__ __	(1) ___	(2) ____	(1) ____	P76 _____
_ 1 2 3 _ 5 6	505	077	__ __	(1) ___	(2) ____	(1) ____	P77 _____
_ 1 2 3 _ 5 _	506	078	__ __	(1) ___	(2) ____	(1) ____	P78 _____
_ 1 2 3 _ _ 6	507	079	__ __	(1) ___	(2) ____	(1) ____	P79 _____
_ 1 2 3 _ _ _	508	080	__ __	(1) ___	(2) ____	(1) ____	P80 _____

RADXPNTS Handler Default values are shown in ( ) or in **bold**

Point Assignments (081 through 120)

POPIT Switch Setting	Trans-lation	Point #	Point Index	Area Assign	Debounce	BFSK/ Relay	Custom Point Text
_ 1 2 _ 4 5 6	509	081	__ __	(1) ___	(2) ____	(1) ____	P81 _____
_ 1 2 _ 4 5 _	510	082	__ __	(1) ___	(2) ____	(1) ____	P82 _____
_ 1 2 _ 4 _ 6	511	083	__ __	(1) ___	(2) ____	(1) ____	P83 _____
_ 1 2 _ 4 _ _	512	084	__ __	(1) ___	(2) ____	(1) ____	P84 _____
_ 1 2 _ _ 5 6	513	085	__ __	(1) ___	(2) ____	(1) ____	P85 _____
_ 1 2 _ _ 5 _	514	086	__ __	(1) ___	(2) ____	(1) ____	P86 _____
_ 1 2 _ _ _ 6	515	087	__ __	(1) ___	(2) ____	(1) ____	P87 _____
_ 1 2 _ _ _ _	516	088	__ __	(1) ___	(2) ____	(1) ____	P88 _____
_ 1 _ 3 4 5 6	601	089	__ __	(1) ___	(2) ____	(1) ____	P89 _____
_ 1 _ 3 4 5 _	602	090	__ __	(1) ___	(2) ____	(1) ____	P90 _____
_ 1 _ 3 4 _ 6	603	091	__ __	(1) ___	(2) ____	(1) ____	P91 _____
_ 1 _ 3 4 _ _	604	092	__ __	(1) ___	(2) ____	(1) ____	P92 _____
_ 1 _ 3 _ 5 6	605	093	__ __	(1) ___	(2) ____	(1) ____	P93 _____
_ 1 _ 3 _ 5 _	606	094	__ __	(1) ___	(2) ____	(1) ____	P94 _____
_ 1 _ 3 _ _ 6	607	095	__ __	(1) ___	(2) ____	(1) ____	P95 _____
_ 1 _ 3 _ _ _	608	096	__ __	(1) ___	(2) ____	(1) ____	P96 _____
_ 1 _ _ 4 5 6	609	097	__ __	(1) ___	(2) ____	(1) ____	P97 _____
_ 1 _ _ 4 5 _	610	098	__ __	(1) ___	(2) ____	(1) ____	P98 _____
_ 1 _ _ 4 _ 6	611	099	__ __	(1) ___	(2) ____	(1) ____	P99 _____
_ 1 _ _ 4 _ _	612	100	__ __	(1) ___	(2) ____	(1) ____	P100 _____
_ 1 _ _ _ 5 6	613	101	__ __	(1) ___	(2) ____	(1) ____	P101 _____
_ 1 _ _ _ 5 _	614	102	__ __	(1) ___	(2) ____	(1) ____	P102 _____
_ 1 _ _ _ _ 6	615	103	__ __	(1) ___	(2) ____	(1) ____	P103 _____
_ 1 _ _ _ _ _	616	104	__ __	(1) ___	(2) ____	(1) ____	P104 _____
_ _ 2 3 4 5 6	701	105	__ __	(1) ___	(2) ____	(1) ____	P105 _____
_ _ 2 3 4 5 _	702	106	__ __	(1) ___	(2) ____	(1) ____	P106 _____
_ _ 2 3 4 _ 6	703	107	__ __	(1) ___	(2) ____	(1) ____	P107 _____
_ _ 2 3 4 _ _	704	108	__ __	(1) ___	(2) ____	(1) ____	P108 _____
_ _ 2 3 _ 5 6	705	109	__ __	(1) ___	(2) ____	(1) ____	P109 _____
_ _ 2 3 _ 5 _	706	110	__ __	(1) ___	(2) ____	(1) ____	P110 _____
_ _ 2 3 _ _ 6	707	111	__ __	(1) ___	(2) ____	(1) ____	P111 _____
_ _ 2 3 _ _ _	708	112	__ __	(1) ___	(2) ____	(1) ____	P112 _____
_ _ 2 _ 4 5 6	709	113	__ __	(1) ___	(2) ____	(1) ____	P113 _____
_ _ 2 _ 4 5 _	710	114	__ __	(1) ___	(2) ____	(1) ____	P114 _____
_ _ 2 _ 4 _ 6	711	115	__ __	(1) ___	(2) ____	(1) ____	P115 _____
_ _ 2 _ 4 _ _	712	116	__ __	(1) ___	(2) ____	(1) ____	P116 _____
_ _ 2 _ _ 5 6	713	117	__ __	(1) ___	(2) ____	(1) ____	P117 _____
_ _ 2 _ _ 5 _	714	118	__ __	(1) ___	(2) ____	(1) ____	P118 _____
_ _ 2 _ _ _ 6	715	119	__ __	(1) ___	(2) ____	(1) ____	P119 _____
_ _ 2 _ _ _ _	716	120	__ __	(1) ___	(2) ____	(1) ____	P120 _____

Default values are shown in ( ) or in **bold** **RADXPNTS Handler**

Point Assignments (121 through 160)

POPIT Switch Setting	Trans-lation	Point #	Point Index	Area Assign	Debounce	BFSK/ Relay	Custom Point Text
_ _ _ 3 4 5 6	801	121	__ __	(1) ___	(2) ____	(1) ____	P121 _____
_ _ _ 3 4 5 _	802	122	__ __	(1) ___	(2) ____	(1) ____	P122 _____
_ _ _ 3 4 _ 6	803	123	__ __	(1) ___	(2) ____	(1) ____	P123 _____
_ _ _ 3 4 _ _	804	124	__ __	(1) ___	(2) ____	(1) ____	P124 _____
_ _ _ 3 _ 5 6	805	125	__ __	(1) ___	(2) ____	(1) ____	P125 _____
_ _ _ 3 _ 5 _	806	126	__ __	(1) ___	(2) ____	(1) ____	P126 _____
_ _ _ 3 _ _ 6	807	127	__ __	(1) ___	(2) ____	(1) ____	P127 _____

ZONEX 1 Maximum

		128	***Not Used***				
0 1 2 3 4 5 6	809	129	__ __	(1) ___	(2) ____	(1) ____	P129 _____
0 1 2 3 4 5 _	810	130	__ __	(1) ___	(2) ____	(1) ____	P130 _____
0 1 2 3 4 _ 6	811	131	__ __	(1) ___	(2) ____	(1) ____	P131 _____
0 1 2 3 4 _ _	812	132	__ __	(1) ___	(2) ____	(1) ____	P132 _____
0 1 2 3 _ 5 6	813	133	__ __	(1) ___	(2) ____	(1) ____	P133 _____
0 1 2 3 _ 5 _	814	134	__ __	(1) ___	(2) ____	(1) ____	P134 _____
0 1 2 3 _ _ 6	815	135	__ __	(1) ___	(2) ____	(1) ____	P135 _____
0 1 2 3 _ _ _	816	136	__ __	(1) ___	(2) ____	(1) ____	P136 _____
0 1 2 _ 4 5 6	117	137	__ __	(1) ___	(2) ____	(1) ____	P137 _____
0 1 2 _ 4 5 _	118	138	__ __	(1) ___	(2) ____	(1) ____	P138 _____
0 1 2 _ 4 _ 6	119	139	__ __	(1) ___	(2) ____	(1) ____	P139 _____
0 1 2 _ 4 _ _	120	140	__ __	(1) ___	(2) ____	(1) ____	P140 _____
0 1 2 _ _ 5 6	121	141	__ __	(1) ___	(2) ____	(1) ____	P141 _____
0 1 2 _ _ 5 _	122	142	__ __	(1) ___	(2) ____	(1) ____	P142 _____
0 1 2 _ _ _ 6	123	143	__ __	(1) ___	(2) ____	(1) ____	P143 _____
0 1 2 _ _ _ _	124	144	__ __	(1) ___	(2) ____	(1) ____	P144 _____
0 1 _ 3 4 5 6	125	145	__ __	(1) ___	(2) ____	(1) ____	P145 _____
0 1 _ 3 4 5 _	126	146	__ __	(1) ___	(2) ____	(1) ____	P146 _____
0 1 _ 3 4 _ 6	127	147	__ __	(1) ___	(2) ____	(1) ____	P147 _____
0 1 _ 3 4 _ _	128	148	__ __	(1) ___	(2) ____	(1) ____	P148 _____
0 1 _ 3 _ 5 6	129	149	__ __	(1) ___	(2) ____	(1) ____	P149 _____
0 1 _ 3 _ 5 _	130	150	__ __	(1) ___	(2) ____	(1) ____	P150 _____
0 1 _ 3 _ _ 6	131	151	__ __	(1) ___	(2) ____	(1) ____	P151 _____
0 1 _ 3 _ _ _	132	152	__ __	(1) ___	(2) ____	(1) ____	P152 _____
0 1 _ _ 4 5 6	217	153	__ __	(1) ___	(2) ____	(1) ____	P153 _____
0 1 _ _ 4 5 _	218	154	__ __	(1) ___	(2) ____	(1) ____	P154 _____
0 1 _ _ 4 _ 6	219	155	__ __	(1) ___	(2) ____	(1) ____	P155 _____
0 1 _ _ 4 _ _	220	156	__ __	(1) ___	(2) ____	(1) ____	P156 _____
0 1 _ _ _ 5 6	221	157	__ __	(1) ___	(2) ____	(1) ____	P157 _____
0 1 _ _ _ 5 _	222	158	__ __	(1) ___	(2) ____	(1) ____	P158 _____
0 1 _ _ _ _ 6	223	159	__ __	(1) ___	(2) ____	(1) ____	P159 _____
0 1 _ _ _ _ _	224	160	__ __	(1) ___	(2) ____	(1) ____	P160 _____

RADXPNTS Handler Default values are shown in ( ) or in **bold**

Point Assignments (161 through 200)

POPIT Switch Setting	Trans-lation	Point #	Point Index	Area Assign	Debounce	BFSK/ Relay	Custom Point Text
0 _ 2 3 4 5 6	225	161	__ __	(1) ___	(2) ____	(1) ____	P161 _____
0 _ 2 3 4 5 _	226	162	__ __	(1) ___	(2) ____	(1) ____	P162 _____
0 _ 2 3 4 _ 6	227	163	__ __	(1) ___	(2) ____	(1) ____	P163 _____
0 _ 2 3 4 _ _	228	164	__ __	(1) ___	(2) ____	(1) ____	P164 _____
0 _ 2 3 _ 5 6	229	165	__ __	(1) ___	(2) ____	(1) ____	P165 _____
0 _ 2 3 _ 5 _	230	166	__ __	(1) ___	(2) ____	(1) ____	P166 _____
0 _ 2 3 _ _ 6	231	167	__ __	(1) ___	(2) ____	(1) ____	P167 _____
0 _ 2 3 _ _ _	232	168	__ __	(1) ___	(2) ____	(1) ____	P168 _____
0 _ 2 _ 4 5 6	317	169	__ __	(1) ___	(2) ____	(1) ____	P169 _____
0 _ 2 _ 4 5 _	318	170	__ __	(1) ___	(2) ____	(1) ____	P170 _____
0 _ 2 _ 4 _ 6	319	171	__ __	(1) ___	(2) ____	(1) ____	P171 _____
0 _ 2 _ 4 _ _	320	172	__ __	(1) ___	(2) ____	(1) ____	P172 _____
0 _ 2 _ _ 5 6	321	173	__ __	(1) ___	(2) ____	(1) ____	P173 _____
0 _ 2 _ _ 5 _	322	174	__ __	(1) ___	(2) ____	(1) ____	P174 _____
0 _ 2 _ _ _ 6	323	175	__ __	(1) ___	(2) ____	(1) ____	P175 _____
0 _ 2 _ _ _ _	324	176	__ __	(1) ___	(2) ____	(1) ____	P176 _____
0 _ _ 3 4 5 6	325	177	__ __	(1) ___	(2) ____	(1) ____	P177 _____
0 _ _ 3 4 5 _	326	178	__ __	(1) ___	(2) ____	(1) ____	P178 _____
0 _ _ 3 4 _ 6	327	179	__ __	(1) ___	(2) ____	(1) ____	P179 _____
0 _ _ 3 4 _ _	328	180	__ __	(1) ___	(2) ____	(1) ____	P180 _____
0 _ _ 3 _ 5 6	329	181	__ __	(1) ___	(2) ____	(1) ____	P181 _____
0 _ _ 3 _ 5 _	330	182	__ __	(1) ___	(2) ____	(1) ____	P182 _____
0 _ _ 3 _ _ 6	331	183	__ __	(1) ___	(2) ____	(1) ____	P183 _____
0 _ _ 3 _ _ _	332	184	__ __	(1) ___	(2) ____	(1) ____	P184 _____
0 _ _ _ 4 5 6	417	185	__ __	(1) ___	(2) ____	(1) ____	P185 _____
0 _ _ _ 4 5 _	418	186	__ __	(1) ___	(2) ____	(1) ____	P186 _____
0 _ _ _ 4 _ 6	419	187	__ __	(1) ___	(2) ____	(1) ____	P187 _____
0 _ _ _ 4 _ _	420	188	__ __	(1) ___	(2) ____	(1) ____	P188 _____
0 _ _ _ _ 5 6	421	189	__ __	(1) ___	(2) ____	(1) ____	P189 _____
0 _ _ _ _ 5 _	422	190	__ __	(1) ___	(2) ____	(1) ____	P190 _____
0 _ _ _ _ _ 6	423	191	__ __	(1) ___	(2) ____	(1) ____	P191 _____
0 _ _ _ _ _ _	424	192	__ __	(1) ___	(2) ____	(1) ____	P192 _____
_ 1 2 3 4 5 6	425	193	__ __	(1) ___	(2) ____	(1) ____	P193 _____
_ 1 2 3 4 5 _	426	194	__ __	(1) ___	(2) ____	(1) ____	P194 _____
_ 1 2 3 4 _ 6	427	195	__ __	(1) ___	(2) ____	(1) ____	P195 _____
_ 1 2 3 4 _ _	428	196	__ __	(1) ___	(2) ____	(1) ____	P196 _____
_ 1 2 3 _ 5 6	429	197	__ __	(1) ___	(2) ____	(1) ____	P197 _____
_ 1 2 3 _ 5 _	430	198	__ __	(1) ___	(2) ____	(1) ____	P198 _____
_ 1 2 3 _ _ 6	431	199	__ __	(1) ___	(2) ____	(1) ____	P199 _____
_ 1 2 3 _ _ _	432	200	__ __	(1) ___	(2) ____	(1) ____	P200 _____

Default values are shown in ( ) or in **bold** **RADXPNTS Handler**

Point Assignments (201 through 239)

POPIT Switch Setting	Trans-lation	Point #	Point Index	Area Assign	Debounce	BFSK/ Relay	Custom Point Text
_ 1 2 _ 4 5 6	517	201	__ __	(1) ___	(2) ____	(1) ____	P201 _____
_ 1 2 _ 4 5 _	518	202	__ __	(1) ___	(2) ____	(1) ____	P202 _____
_ 1 2 _ 4 _ 6	519	203	__ __	(1) ___	(2) ____	(1) ____	P203 _____
_ 1 2 _ 4 _ _	520	204	__ __	(1) ___	(2) ____	(1) ____	P204 _____
_ 1 2 _ _ 5 6	521	205	__ __	(1) ___	(2) ____	(1) ____	P205 _____
_ 1 2 _ _ 5 _	522	206	__ __	(1) ___	(2) ____	(1) ____	P206 _____
_ 1 2 _ _ _ 6	523	207	__ __	(1) ___	(2) ____	(1) ____	P207 _____
_ 1 2 _ _ _ _	524	208	__ __	(1) ___	(2) ____	(1) ____	P208 _____
_ 1 _ 3 4 5 6	525	209	__ __	(1) ___	(2) ____	(1) ____	P209 _____
_ 1 _ 3 4 5 _	526	210	__ __	(1) ___	(2) ____	(1) ____	P210 _____
_ 1 _ 3 4 _ 6	527	211	__ __	(1) ___	(2) ____	(1) ____	P211 _____
_ 1 _ 3 4 _ _	528	212	__ __	(1) ___	(2) ____	(1) ____	P212 _____
_ 1 _ 3 _ 5 6	529	213	__ __	(1) ___	(2) ____	(1) ____	P213 _____
_ 1 _ 3 _ 5 _	530	214	__ __	(1) ___	(2) ____	(1) ____	P214 _____
_ 1 _ 3 _ _ 6	531	215	__ __	(1) ___	(2) ____	(1) ____	P215 _____
_ 1 _ 3 _ _	532	216	__ __	(1) ___	(2) ____	(1) ____	P216 _____
_ 1 _ _ 4 5 6	617	217	__ __	(1) ___	(2) ____	(1) ____	P217 _____
_ 1 _ _ 4 5 _	618	218	__ __	(1) ___	(2) ____	(1) ____	P218 _____
_ 1 _ _ 4 _ 6	619	219	__ __	(1) ___	(2) ____	(1) ____	P219 _____
_ 1 _ _ 4 _ _	620	220	__ __	(1) ___	(2) ____	(1) ____	P220 _____
_ 1 _ _ _ 5 6	621	221	__ __	(1) ___	(2) ____	(1) ____	P221 _____
_ 1 _ _ _ 5 _	622	222	__ __	(1) ___	(2) ____	(1) ____	P222 _____
_ 1 _ _ _ _ 6	623	223	__ __	(1) ___	(2) ____	(1) ____	P223 _____
_ 1 _ _ _ _ _	624	224	__ __	(1) ___	(2) ____	(1) ____	P224 _____
_ _ 2 3 4 5 6	625	225	__ __	(1) ___	(2) ____	(1) ____	P225 _____
_ _ 2 3 4 5 _	626	226	__ __	(1) ___	(2) ____	(1) ____	P226 _____
_ _ 2 3 4 _ 6	627	227	__ __	(1) ___	(2) ____	(1) ____	P227 _____
_ _ 2 3 4 _ _	628	228	__ __	(1) ___	(2) ____	(1) ____	P228 _____
_ _ 2 3 _ 5 6	629	229	__ __	(1) ___	(2) ____	(1) ____	P229 _____
_ _ 2 3 _ 5 _	630	230	__ __	(1) ___	(2) ____	(1) ____	P230 _____
_ _ 2 3 _ _ 6	631	231	__ __	(1) ___	(2) ____	(1) ____	P231 _____
_ _ 2 3 _ _ _	632	232	__ __	(1) ___	(2) ____	(1) ____	P232 _____
_ _ 2 _ 4 5 6	717	233	__ __	(1) ___	(2) ____	(1) ____	P233 _____
_ _ 2 _ 4 5 _	718	234	__ __	(1) ___	(2) ____	(1) ____	P234 _____
_ _ 2 _ 4 _ 6	719	235	__ __	(1) ___	(2) ____	(1) ____	P235 _____
_ _ 2 _ 4 _ _	720	236	__ __	(1) ___	(2) ____	(1) ____	P236 _____
_ _ 2 _ _ 5 6	721	237	__ __	(1) ___	(2) ____	(1) ____	P237 _____
_ _ 2 _ _ 5 _	722	238	__ __	(1) ___	(2) ____	(1) ____	P238 _____
_ _ 2 _ _ _ 6	723	239	__ __	(1) ___	(2) ____	(1) ____	P239 _____

RADXPNTS Handler Default values are shown in ( ) or in **bold**

Point Assignments (240 through 247)

POPIT Switch Setting	Trans-lation	Point #	Point Index	Area Assign	Debounce	BFSK/ Relay	Custom Point Text
_ _ 2 _ _ _ _	724	240*	__ __	(1) ___	(2) ____	(1) ____	P240 _____
_ _ _ 3 4 5 6	725	241*	__ __	(1) ___	(2) ____	(1) ____	P241 _____
_ _ _ 3 4 5 _	726	242*	__ __	(1) ___	(2) ____	(1) ____	P242 _____
_ _ _ 3 4 _ 6	727	243*	__ __	(1) ___	(2) ____	(1) ____	P243 _____
_ _ _ 3 4 _ _	728	244*	__ __	(1) ___	(2) ____	(1) ____	P244 _____
_ _ _ 3 _ 5 6	729	245*	__ __	(1) ___	(2) ____	(1) ____	P245 _____
_ _ _ 3 _ 5 _	730	246*	__ __	(1) ___	(2) ____	(1) ____	P246 _____
_ _ _ 3 _ _ 6	731	247*	__ __	(1) ___	(2) ____	(1) ____	P247 _____

**The Point Text for Points 240 to 247 can be used for the Area Name Text when a D1260 Alpha V Command Center is used. Point 240 Text is used as Area 1's Area Name Text, Point 241Text is used as Area 2's Area Name Text, …and Point 247 Text is used as Area 8's Area Name Text.*

CMD 7 and CMD 9

Command	Point Index	BFSK/Relay	Point Text
COMMAND 7	(31) _____	(1) _____	COMMAND 7 _____
COMMAND 9	(31) _____	(1) _____	COMMAND 9 _____

Default values are shown in ( ) or in **bold** **RADXSKED Handler**

Windows

Opening and Closing

	W# 1	W# 2	W# 3	W# 4	W# 5	W# 6	W# 7	W# 8
Day of Week								
Sunday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Monday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Tuesday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Wednesday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Thursday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Friday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Saturday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Open								
Early Begin	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__
Window Start	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__
Window Stop	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__
Close								
Early Begin	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__
Window Start	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__
Window Stop	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__
Holidays								
Xept Holiday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 1	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 2	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 3	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 4	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Areas								
Area 1	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Area 2	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Area 3	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Area 4	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Area 5	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Area 6	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Area 7	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Area 8	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**

Use this table to determine the appropriate entries for your application.

Open/Close Window Activation	Day of Week	Xept Holiday	Holiday Index	Area(s)
Day(s) of the week	Program at least one Day as YES.	No	None	Program at least one Area as YES.
Days(s) of the Week, but NOT on Holidays	Program at least one Day as YES.	Yes	Select at least one Index.	Program at least one Area as YES.
Day(s) of the Week, PLUS Holidays	Program at least one Day as YES.	No	Select at least one Index.	Program at least one Area as YES.
Only on Holidays	All Days must be programmed NO.	No	Select at least one Index.	Program at least one Area as YES.

RADXSKED Handler Default values are shown in ( ) or in **bold**

Windows (continued)

User Group

	UW#1	UW#2	UW#3	UW#4	UW#5	UW#6	UW#7	UW#8
User Group	_____ (1)	_____ (1)	_____ (1)	_____ (1)	_____ (1)	_____ (1)	_____ (1)	_____ (1)
Day of Week								
Sunday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Monday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Tuesday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Wednesday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Thursday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Friday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Saturday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Group								
Enable Time	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__
Disable Time	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__
Holidays								
Xept Holiday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 1	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 2	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 3	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 4	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**

Default values are shown in ( ) or in **bold** **RADXSKED Handler**

Skeds

Skeds 1 to 10

	Sked 1	Sked 2	Sked 3	Sked 4	Sked 5	Sked 6	Sked 7	Sked 8	Sked 9	Sked 10
Time Edit	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No
Function Code	_ _	_ _	_ _	_ _	_ _	_ _	_ _	_ _	_ _	_ _
Parameter 1	_____	_____	_____	_____	_____	_____	_____	_____	_____	_____
Parameter 2	_____	_____	_____	_____	_____	_____	_____	_____	_____	_____
Time	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__
Date	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _
Day of Week										
Sunday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Monday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Tuesday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Wednesday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Thursday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Friday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Saturday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holidays										
Xept Holiday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 1	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 2	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 3	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 4	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**

Skeds 11 to 20

	Sked 11	Sked 12	Sked 13	Sked 14	Sked 15	Sked 16	Sked 17	Sked 18	Sked 19	Sked 20
Time Edit	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No
Function Code	_ _	_ _	_ _	_ _	_ _	_ _	_ _	_ _	_ _	_ _
Parameter 1	_____	_____	_____	_____	_____	_____	_____	_____	_____	_____
Parameter 2	_____	_____	_____	_____	_____	_____	_____	_____	_____	_____
Time	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__
Date	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _
Day of Week										
Sunday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Monday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Tuesday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Wednesday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Thursday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Friday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Saturday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holidays										
Xept Holiday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 1	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 2	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 3	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 4	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**

RADXSKED Handler Default values are shown in ( ) or in **bold**

Skeds (continued)

Skeds 21 to 30

	Sked 21	Sked 22	Sked 23	Sked 24	Sked 25	Sked 26	Sked 27	Sked 28	Sked 29	Sked 30
Time Edit	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No
Function Code	_ _	_ _	_ _	_ _	_ _	_ _	_ _	_ _	_ _	_ _
Parameter 1	_____	_____	_____	_____	_____	_____	_____	_____	_____	_____
Parameter 2	_____	_____	_____	_____	_____	_____	_____	_____	_____	_____
Time	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__
Date	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _
Day of Week										
Sunday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Monday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Tuesday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Wednesday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Thursday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Friday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Saturday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holidays										
Xept Holiday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 1	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 2	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 3	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 4	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**

Skeds 31 to 40

	Sked 31	Sked 32	Sked 33	Sked 34	Sked 35	Sked 36	Sked 37	Sked 38	Sked 39	Sked 40
Time Edit	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No	**Yes**/No
Function Code	_ _	_ _	_ _	_ _	_ _	_ _	_ _	_ _	_ _	_ _
Parameter 1	_____	_____	_____	_____	_____	_____	_____	_____	_____	_____
Parameter 2	_____	_____	_____	_____	_____	_____	_____	_____	_____	_____
Time	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__	__:__
Date	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _	_ _/_ _
Day of Week										
Sunday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Monday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Tuesday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Wednesday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Thursday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Friday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Saturday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holidays										
Xept Holiday	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 1	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 2	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 3	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**
Holiday 4	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**	Yes/**No**

Skeds (continued)

Sked Function Codes

Function	Function Code	Parameter 1		Parameter 2	
		Description	Selection	Description	Selection
Blank Not in use (all inactive Skeds must have a Blank entry in Function Code for panel efficiency).					
Arm Area	1	Area **1** Area **2** Area **3** Area **4** Area **5** Area **6** Area **7** Area **8**	Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No**		
Disarm Area	2	Area **1** Area **2** Area **3** Area **4** Area **5** Area **6** Area **7** Area **8**	Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No**		
Bypass a Point A point can be bypassed only if it is programmed to allow bypassing in Point Parameters. The bypassed point is reported if Bypass Reports is programmed Yes for the point. †*Points 76 to 127 and 129 to 247 are available with the D9112, D9412, and D9412G only.*	3	Point Number	Blank, 1 - 75, 76 – 127,† 129 - 247†		
Unbypass a Point †*Points 76 to 127 and 129 to 247 are available with the D9112, D9412, and D9412G only.*	4	Point Number	Blank, 1 - 75, 76 – 127,† 129 - 247†		
Unbypass All Points	5	Area **1** Area **2** Area **3** Area **4** Area **5** Area **6** Area **7** Area **8**	Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No**		
Relay On †*Relays 65 to 128 are available with the D9112, D9412, and D9412G only.*	6	Relay Number	Blank, 1 - 64, 65 - 128†		
Relay Off †*Relays 65 to 128 are available with the D9112, D9412, and D9412G only.*	7	Relay Number	Blank, 1 - 64, 65 - 128†		
All Relays Off	8	None			

Skeds (continued)

Sked Function Codes (continued)

Function	Function Code	Parameter 1		Parameter 2	
		Description	Selection	Description	Selection
Blank Not in use (all inactive Skeds must have a Blank entry in Function Code for panel efficiency).					
Test Report Generates a test report. The report is sent to the Phone(s) programmed in the Phone Routing Chart.	9	Defer Test	Yes / **No**	Hourly Test Report	Yes / **No**
Status Report	10	Defer Status	Yes / **No**		
Execute Custom Function **Not a valid entry if Parameter 1 is a non-zero value.* *†Custom Functions 132 to 143 are available with the D9112, D9412, and D9412G only.*	11	Cmd Center	0 = default 1 - 8	Custom Function	0 = default* 128 - 131, 132 - 143†
Not Used	12				
Adjust Time Forward 1 Hour (Daylight Savings Time adjustment)	13	None			
Adjust Time Backward 1 Hour (Daylight Savings Time adjustment)	14	None			
Sound Watch at Command Center	15	CC **1** CC **2** CC **3** CC **4** CC **5** CC **6** CC **7** CC **8**	Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No**		
Access Control Level On *Function available with the D7412, D7412G, D9412, and D9412G only.*	16	Level **1** Level **2** Level **3** Level **4** Level **5** Level **6** Level **7** Level **8** Level **9** Level **10** Level **11** Level **12** Level **13** Level **14**	Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No**		

Skeds (continued)

Sked Function Codes (continued)

Function	Function Code	Parameter 1		Parameter 2	
		Description	Selection	Description	Selection
Blank Not in use (all inactive Skeds must have a Blank entry in Function Code for panel efficiency).					
Access Control Level Off *Function available with the D7412, D7412G, D9412, and D9412G only.*	17	Level **1** Level **2** Level **3** Level **4** Level **5** Level **6** Level **7** Level **8** Level **9** Level **10** Level **11** Level **12** Level **13** Level **14**	Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No**		
Unlock Door *Function available with the D7412, D7412G, D9412, and D9412G only.* *Maximum is 2 Access Doors for the D7412 and D7412G.*	18	Door **1** Door **2** Door **3** Door **4** Door **5** Door **6** Door **7** Door **8**	Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No**		
Secure Door *Function available with the D7412, D7412G, D9412, and D9412G only.* *Maximum is 2 Access Doors for the D7412 and D7412G.*	19	Door **1** Door **2** Door **3** Door **4** Door **5** Door **6** Door **7** Door **8**	Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No**		
Lock Door *Function available with the D7412, D7412G, D9412, and D9412G only.* *Maximum is 2 Access Doors for the D7412 and D7412G.*	20	Door **1** Door **2** Door **3** Door **4** Door **5** Door **6** Door **7** Door **8**	Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No**		

Skeds (continued)

Sked Function Codes (continued)

Function	Function Code	Parameter 1		Parameter 2	
		Description	Selection	Description	Selection
Blank Not in use (all inactive Skeds must have a Blank entry in Function Code for panel efficiency).					
Access Granted Events On *Function available with the D7412, D7412G, D9412, and D9412G only.* *Maximum is 2 Access Doors for the D7412 and D7412G.*	21	Door **1** Door **2** Door **3** Door **4** Door **5** Door **6** Door **7** Door **8**	Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No**		
Access Granted Events Off *Function available with the D7412, D7412G, D9412, and D9412G only.* *Maximum is 2 Access Doors for the D7412 and D7412G.*	22	Door **1** Door **2** Door **3** Door **4** Door **5** Door **6** Door **7** Door **8**	Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No**		
Access Denied Events On *Function available with the D7412, D7412G, D9412, and D9412G only.* *Maximum is 2 Access Doors for the D7412 and D7412G.*	23	Door **1** Door **2** Door **3** Door **4** Door **5** Door **6** Door **7** Door **8**	Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No**		
Access Denied Events Off *Function available with the D7412, D7412G, D9412, and D9412G only.* *Maximum is 2 Access Doors for the D7412 and D7412G.*	24	Door **1** Door **2** Door **3** Door **4** Door **5** Door **6** Door **7** Door **8**	Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No** Yes / **No**		
Expanded Off-Normal Test Report	28	None			
Non-Expanded Off-Normal Test Report	29	None			

Default values are shown in ( ) or in **bold** **RADXSKED Handler**

Skeds (continued)

Holiday Indexes

	Holiday Index #					*Holiday Index #*					*Holiday Index #*			
Date	**1**	**2**	**3**	**4**	**Date**	**1**	**2**	**3**	**4**	**Date**	**1**	**2**	**3**	**4**
Jan 1					Feb 1					Mar 1				
2					2					2				
3					3					3				
4					4					4				
5					5					5				
6					6					6				
7					7					7				
8					8					8				
9					9					9				
10					10					10				
11					11					11				
12					12					12				
13					13					13				
14					14					14				
15					15					15				
16					16					16				
17					17					17				
18					18					18				
19					19					19				
20					20					20				
21					21					21				
22					22					22				
23					23					23				
24					24					24				
25					25					25				
26					26					26				
27					27					27				
28					28					28				
29					29					29				
30										30				
31										31				

	Holiday Index #					*Holiday Index #*					*Holiday Index #*			
Date	**1**	**2**	**3**	**4**	**Date**	**1**	**2**	**3**	**4**	**Date**	**1**	**2**	**3**	**4**
Apr 1					May 1					Jun 1				
2					2					2				
3					3					3				
4					4					4				
5					5					5				
6					6					6				
7					7					7				
8					8					8				
9					9					9				
10					10					10				
11					11					11				
12					12					12				
13					13					13				
14					14					14				
15					15					15				
16					16					16				
17					17					17				
18					18					18				
19					19					19				
20					20					20				
21					21					21				
22					22					22				
23					23					23				
24					24					24				
25					25					25				
26					26					26				
27					27					27				
28					28					28				
29					29					29				
30					30					30				
					31									

RADXSKED Handler Default values are shown in ( ) or in **bold**

Skeds (continued)

Holiday Indexes (continued)

	Holiday Index #					*Holiday Index #*					*Holiday Index #*			
Date	**1**	**2**	**3**	**4**	**Date**	**1**	**2**	**3**	**4**	**Date**	**1**	**2**	**3**	**4**
Jul 1					Aug 1					Sep 1				
2					2					2				
3					3					3				
4					4					4				
5					5					5				
6					6					6				
7					7					7				
8					8					8				
9					9					9				
10					10					10				
11					11					11				
12					12					12				
13					13					13				
14					14					14				
15					15					15				
16					16					16				
17					17					17				
18					18					18				
19					19					19				
20					20					20				
21					21					21				
22					22					22				
23					23					23				
24					24					24				
25					25					25				
26					26					26				
27					27					27				
28					28					28				
29					29					29				
30					30					30				
31					31									

	Holiday Index #					*Holiday Index #*					*Holiday Index #*			
Date	**1**	**2**	**3**	**4**	**Date**	**1**	**2**	**3**	**4**	**Date**	**1**	**2**	**3**	**4**
Oct 1					Nov 1					Dec 1				
2					2					2				
3					3					3				
4					4					4				
5					5					5				
6					6					6				
7					7					7				
8					8					8				
9					9					9				
10					10					10				
11					11					11				
12					12					12				
13					13					13				
14					14					14				
15					15					15				
16					16					16				
17					17					17				
18					18					18				
19					19					19				
20					20					20				
21					21					21				
22					22					22				
23					23					23				
24					24					24				
25					25					25				
26					26					26				
27					27					27				
28					28					28				
29					29					29				
30					30					30				
31										31				

Default values are shown in ( ) or in **bold** **RADXAUX1 Handler**

SDI Automation

Enable SDI Auto	Yes / **No**	9133 Supervision	Yes / **No**	DTR Control (On)	_____
Baud Rate (9600)	_____	RTS Control (On)	_____	Status Rate (0)	_____
Parity / Stop (No / 1)	_____		_____		

SDI RAM Parameters

Enable SDI RAM	**Yes** / No	RAM IP Address 4 (0)	_____	RAM Line Monitor	Yes / **No**
Call Back Enabled	Yes / **No**	Enable External Modem	Yes / **No**	Seize Relay	Yes / **No**
RAM IP Address 1 (0)	_____	Answer Armed (7)	_____	Modem Init String (ATEO)	_____
RAM IP Address 2 (0)	_____	Answer Disarmed (7)	_____	RAM Dial String (ATDT)	_____
RAM IP Address 3 (0)	_____				

Enhanced Communication

Enable Enhanced Comm Yes / **No**

Path 1 IP Add1 (0)	___	Path 2 IP Add1 (0)	___	Path 3 IP Add1 (0)	___	Path 4 IP Add1 (0)	___
Path 1 IP Add2 (0)	___	Path 2 IP Add2 (0)	___	Path 3 IP Add2 (0)	___	Path 4 IP Add2 (0)	___
Path 1 IP Add3 (0)	___	Path 2 IP Add3 (0)	___	Path 3 IP Add3 (0)	___	Path 4 IP Add3 (0)	___
Path 1 IP Add4 (0)	___	Path 2 IP Add4 (0)	___	Path 3 IP Add4 (0)	___	Path 4 IP Add4 (0)	___
Path 1 Poll Rate (0)	___	Path 2 Poll Rate (0)	___	Path 3 Poll Rate (0)	___	Path 4 Poll Rate (0)	___
Path 1 Ack Wait (13)	___	Path 2 Ack Wait (13)	___	Path 3 Ack Wait (13)	___	Path 4 Ack Wait (13)	___
Path 1 Retry Count (5)	___	Path 2 Retry Count (5)	___	Path 3 Retry Count (5)	___	Path 4 Retry Count (5)	___

Route Group Attempts

RG1 1 Attempt	Yes / **No**	RG3 1 Attempt	Yes / **No**
RG2 1 Attempt	Yes / **No**	RG4 1 Attempt	Yes / **No**

SDI RAM / Enhanced Communication Configuration

Baud Rate (9600)	_____	DTR Control (On)	_____
Parity / Stop (No / 1)	_____	9133 Supervision	Yes / **No**
RTS Control (On)	_____	Base Port Number (7700)	_____

Miscellaneous

Fire Supv Res Event (0)	_____	Enable Anti Replay	Yes / **No**
Enable Protocol Type	Yes / **No**	Fire Trouble Resound (0)	_____

Cross Point Parameters

Cross Point Time (20) _____

D9133 Serial Interface Module

There are no jumper settings required for the D9133 (SDI Address 80) for home or building automation purposes. All jumper shunts must be removed for this setting.



Note: RPS version 2.8 and higher must be used to view info on this page.

D9133TTL-E Network Interface Module

A jumper must be placed over Pin 8 for the D9133TTL-E (SDI Address 88) to be used for RPS and/or alternate communications in a LAN/WAN application.



Note: The D9133DC Direct Connect Programming Module, when used for local RPS programming, must be set to Address 88.

RADXAXS Handler Default values are shown in ( ) or in **bold**

Door Profile

	Door 1	Door 2	Door 3†	Door 4†	Door 5†	Door 6†	Door 7†	Door 8†
Entry Area # (blank)	_____	_____	_____	_____	_____	_____	_____	_____
CC# Scope (1)	_____	_____	_____	_____	_____	_____	_____	_____
Door Point (blank)*	_____	_____	_____	_____	_____	_____	_____	_____
Interlock Point (blank)*	_____	_____	_____	_____	_____	_____	_____	_____
Auto Door?	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Fire Unlock?	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Disarm On Open?	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
Card Type**	0	0	0	0	0	0	0	0

* *Points 128 and 248 are reserved for an internal panel function and not valid selections. When using the D7412, the valid point range is 1 to 75.*

** *Although Card Type is visible, this prompt must remain at 0 for 26 bit Wiegand format.*

† *Doors 3 through 8 available with the D9412 and D9412G only.*

Strike Profile

	Door 1	Door 2	Door 3†	Door 4†	Door 5†	Door 6†	Door 7†	Door 8†
Strike Time (10)	_____	_____	_____	_____	_____	_____	_____	_____
Shunt Time (10)	_____	_____	_____	_____	_____	_____	_____	_____
Buzz Time (2)	_____	_____	_____	_____	_____	_____	_____	_____
Extend Time (10)	_____	_____	_____	_____	_____	_____	_____	_____
Deactivate On Open?	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No	**Yes** / No
RTE Shunt Only?	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
REX Shunt Only?	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**

† *Doors 3 through 8 available with the D9412 and D9412G only.*

Event Profile

	Door 1	Door 2	Door 3†	Door 4†	Door 5†	Door 6†	Door 7†	Door 8†
Access Granted?	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
No Entry?	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Enter Request?	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**
Exit Request?	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**	Yes / **No**

† *Doors 3 through 8 available with the D9412 and D9412G only.*

Door Information

Door 1	Door 5
Door 2	Door 6
Door 3	Door 7
Door 4	Door 8

D9210B Switch Settings

Door Controller	Address Switches*					
	1	2	3	4	5	6
1	On	On	On	On	On	On
2	Off	On	On	On	On	On
3†	On	Off	On	On	On	On
4†	Off	Off	On	On	On	On
5†	On	On	Off	On	On	On
6†	Off	On	Off	On	On	On
7†	On	Off	Off	On	On	On
8†	Off	Off	Off	On	On	On

Note: On = SDI Fail Open (default), Off = SDI Fail Door Close
**Switches 1-3: Address Setting, Switch 4: Fail Safe Mode, Switches 5 & 6 must stay in the "On" position.*
†Available with the D9412 and D9412G only.

Printer Address Settings

Printer	Address Switches					
	1	2	3	4*	5	6
17	On	On	On	On	On	On
18†	Off	On	On	On	On	On
19†	On	Off	On	On	On	On

**Switch 4: On = Header and Form Feed (default), Off = No Header or Form Feed*
†Available with the D9112, D9412, and D9412G only.

D8128C OctoPOPIT Switch Settings

ZONEX 1** Points 9 to 120	Address Switches					ZONEX 2** Points 129 to 240
	0	1	2	3	4	
9-16	On	On	On	On	*	129-136†
17-24	On	On	On	Off	*	137-144†
25-32	On	On	Off	On	*	145-152†
33-40	On	On	Off	Off	*	153-160†
41-48	On	Off	On	On	*	161-168†
49-56	On	Off	On	Off	*	169-176†
57-64	On	Off	Off	On	*	177-184†
65-72	On	Off	Off	Off	*	185-192†
73-80†	Off	On	On	On	*	193-200†
81-88†	Off	On	On	Off	*	201-208†
89-96†	Off	On	Off	On	*	209-216†
97-104†	Off	On	Off	Off	*	217-224†
105-112†	Off	Off	On	On	*	225-232†
113-120†	Off	Off	On	Off	*	233-240†
121-127***	**Do Not Use D8128C**					**241-247*****

**Line Termination Switch*
***D9112, D9124, and D9412 use Points 9-120 on ZONEX 1 and Points 129-240 on ZONEX 2.*
****When using D8128C OctoPOPITs, use a D8125 POPEX module and D9127 POPIT modules for configuring Points 121-127 and Points 241-247.*

†Available with the D9412G only.

Command Center Assignments

Address #	Address Switches					
	1	2	3	4	5*	6
Address 1	On	On	On	On	On	On
Address 2	Off	On	On	On	On	On
Address 3	On	Off	On	On	On	On
Address 4	Off	Off	On	On	On	On
Address 5	On	On	Off	On	On	On
Address 6	Off	On	Off	On	On	On
Address 7	On	Off	Off	On	On	On
Address 8	Off	Off	Off	On	On	On

**Switch 5: On = Encoding Tone On (default), Off = Encoding Tone Off*

OctoRelay Switch Settings

ZONEX 1 Terminal 28 Relays 1 to 64	Address Switches				ZONEX 2 Terminal 26 Relays 65 to 128
	1	2	3	4	
1 – 8	Off	On	On	On	65 – 72†
9 – 16	On	Off	On	On	73 – 80†
17 – 24	Off	Off	On	On	81 – 88†
25 – 32	On	On	Off	On	89 – 96†
33 – 40	Off	On	Off	On	97 – 104†
41 – 48	On	Off	Off	On	105 – 112†
49 – 56	Off	Off	Off	On	113 – 120†
57 – 64	On	On	On	Off	121 - 128†

†Available with the D9112, D9412, and D9412G only.

D8128D OctoPOPIT Switch Settings

ZONEX 1 Points 9 to 127	Address Switches					ZONEX 2 Points 129 to 247
	1	2	3	4	5	
9-16	On	On	On	On	*	129-136†
17-24	On	On	On	Off	*	137-144†
25-32	On	On	Off	On	*	145-152†
33-40	On	On	Off	Off	*	153-160†
41-48	On	Off	On	On	*	161-168†
49-56	On	Off	On	Off	*	169-176†
57-64	On	Off	Off	On	*	177-184†
65-72	On	Off	Off	Off	*	185-192†
73-80†	Off	On	On	On	*	193-200†
81-88†	Off	On	On	Off	*	201-208†
89-96†	Off	On	Off	On	*	209-216†
97-104†	Off	On	Off	Off	*	217-224†
105-112†	Off	Off	On	On	*	225-232†
113-120†	Off	Off	On	Off	*	233-240†
121-127**†	Off	Off	Off	On	*	241-247**†

**Line Termination Switch*
***For the OctoPOPITs assigned to Points 121-127 and Points 241-247, be sure to set Point Input Switch 8 to the OPEN position.*
†Available with the D9112, D9412, and D9412G only.

Bosch Security Systems
130 Perinton Parkway
Fairport, NY 14450-9199
Customer Service: (800) 289-0096
Technical Support: (888) 886-6189

47488F

© 2004 Bosch Security Systems
47488F