Quick Guide Operating Instructions

(Advent Commercial Fire System 60-562-03, 60-562-06)

Commands at a Glance

То	Steps
Acknowledge/Cancel an Alarm or Drill	 Turn keyswitch (if any) on. Press both ACKNOWLEDGE buttons. Enter ACCESS CODE if prompted. Turn keyswitch (if any) off.
Silence an Alarm	 Turn keyswitch (if any) on. Press both SILENCE buttons. Enter ACCESS CODE if prompted. Turn keyswitch (if any) off.
Conduct a Fire Drill	 Turn keyswitch (if any) on. Press and hold both DRILL buttons for 2 seconds. Enter ACCESS CODE if prompted. Turn keyswitch (if any) off.
Reset Smoke Sensors	 Turn keyswitch (if any) on. Press RESET button. Enter ACCESS CODE if prompted. Turn keyswitch (if any) off.
View Active Alarms (during an alarm)	Repeatedly press the ENTER (#) button.
View System Main Menu (not during an alarm)	Press the undo (*) or ENTER (#) button.

Duration of visual and audible alarm adjustable by installer. Set at _____.

Dealer		
Dealer Phone Number:()		
Dealer Address:		
Installation Date:	Installer Initials:	

This system is intended to be checked by a qualified technician at least every three years.

These instructions must be framed and placed next to the control panel.