

**NX-8 CONTROL PANEL**  
ADDENDUM TO REVISION "S" INSTALLATION MANUAL  
01-FEBRUARY-2005

Revisions to UL Requirements (Page 58 of the installation manual):

When installing an NX-8 in compliance with Underwriters Laboratories, the following instructions must be observed:

- The 4-wire smoke detector employed shall be rated to operate over the voltage range of 11.5 to 12.4V.
- Compatible listed devices: (Special Applications)
  - Bell Output (Sirens): Wheelock models: NS-1215W, NS-121575W, NS4-1215W, NS4-121575W, AS-1215W, AS-121575W
  - Horn / Strobe: System Sensor: S1224MC Strobe series; 1224MC Horn/Strobe series; H12/24 Horn series
  - Smoke Output (4 wire detectors):
    - ESL: 500N series; 449CTE series; 521 series; 541 series
    - System Sensor models: 2112/24R; 2112/24TR; 2112/24AT; 2112/ATR; 2112/24AATR; 4WTA-B; 4WTR-B; 4WTAR-B; 4WITAR-B.
    - Detection Systems: F220-B6C; D273 series
    - Hochiki: SBC-4/12, 4/12W

---

**NX-8 CONTROL PANEL**  
ADDENDUM TO REVISION "S" INSTALLATION MANUAL  
01-FEBRUARY-2005

Revisions to UL Requirements (Page 58 of the installation manual):

When installing an NX-8V2 in compliance with Underwriters Laboratories, the following instructions must be observed:

- The 4-wire smoke detector employed shall be rated to operate over the voltage range of 11.5 to 12.4V.
- Compatible listed devices: (Special Applications)
  - Bell Output (Sirens): Wheelock models: NS-1215W, NS-121575W, NS4-1215W, NS4-121575W, AS-1215W, AS-121575W
  - Horn / Strobe: System Senso : S1224MC Strobe series; 1224MC Horn/Strobe series; H12/24 Horn series
  - Smoke Output (4 wire detectors):
    - ESL: 500N series; 449CTE series; 521 series; 541 series
    - System Sensor models: 2112/24R; 2112/24TR; 2112/24AT; 2112/ATR; 2112/24AATR; 4WTA-B; 4WTR-B; 4WTAR-B; 4WITAR-B.
    - Detection Systems: F220-B6C; D273 series
    - Hochiki: SBC-4/12, 4/12W